

**PRELIMINARY
NOT FOR CONSTRUCTION**

Davidson Middle School Mechanical Upgrades Structural Calculations

San Rafael, CA
ZFA Project Number: 21650

Structural Calcs_V1

January 7, 2022

Prepared For:
QKA
Santa Rosa, CA



01/10/2022

Prepared By:
Benny Cope, Designer
Dudley Mei, PE, Engineer
Chris Warner, SE, Principal-in-Charge
Santa Rosa, California

ZFA STRUCTURAL ENGINEERS

Job #21650

TOC

Engineer: BVC; DM

1/3/2022

Davidson MS HVAC

TABLE OF CONTENTS

<u>Description</u>	<u>Page</u>
Structural Narrative	3
Design Criteria	4-9
Flat Weights	10
Shear Wall Capacity Check	11
Anchorage	12-37

ZFA STRUCTURAL ENGINEERS

Job #21650
Structural Narrative

Engineer: BVC; DM
1/3/2022

Davidson MS HVAC

STRUCTURAL NARRATIVE

The structural calculations contained herein reflect mechanical modifications at the annex, maker space, band room and music room of Davidson Middle School. The effective seismic weights of the buildings will not increase by 10% and the effective seismic weight tributary to each shear wall line will not increase by more than 5%, hence no structural rehabilitation is required per CAC 4-309(c).

At the annex, new intake louvers at the roof will not increase the total gravity load by more than 5%, therefore (E) framing is okay. A widened intake louver at an (E) shear wall will not reduce its stiffness by more than 5% and therefore does not require rehabilitation per CAC 4-309. Anchorage for a wall-mounted electrical panel in the annex was also calculated.

Additional anchorage calculations are provided for fan coil units, pipe supports and duct supports.

Calculations were not required for furnace, condensing and HP units which have a center of gravity less than four feet above ground and weigh under four-hundred pounds per the exemptions of CBC 1617A.1.18.

ZFA STRUCTURAL ENGINEERS

Job #21650
Design Criteria

Engineer: BVC; DM
1/3/2022

Davidson MS HVAC

DETAILED DESIGN CRITERIA

BUILDING CODE

Governing Code:	2019 California Building Code
Authority Having Jurisdiction:	DSA
Local Codes or Amendments:	0



BUILDING SYSTEM DESCRIPTION

No. Stories:	1
Footprint:	Varies ft ²
Floor Area:	Varies ft ²
Roof Area:	Varies ft ²
Mean Building Height:	11 ft
Roof Pitch:	Varies :12

Building Use:	Educational
Gravity System:	Wood Bearing Walls
Diaphragm System:	Plywood Sheathing
Foundation System:	Concrete Footings

ZFA STRUCTURAL ENGINEERSJob #21650
Design CriteriaEngineer: BVC; DM
1/3/2022

Davidson MS HVAC

DETAILED DESIGN CRITERIAASCE 7-16 Reference
UNO:**SEISMIC DESIGN PARAMETERS**

Analysis Procedure Used:	EQ (Equiv. Lat. Force, 12.8)		Section 12.6
Latitude:	37.9659 deg	Longitude:	-122.5249 deg
Risk Category:	III	Educational	Table 1.5-1
$I_E =$	1.25	Importance Factor, Seismic	Table 1.5-1
$I_P =$	1.00	Importance Factor, Nonstructural Components	13.1.3
Soil Site Class =	D (by default)	Per Geotech Report, Site Class D otherwise	Table 20.3-1
$S_S =$	1.500 g	Mapped spectral response acceleration parameter	USGS
$S_1 =$	0.600 g	Mapped spectral response acceleration parameter	USGS
$F_a =$	1.2	Site coefficient	Table 11.4-1
$F_v =$	1.7	Site coefficient	Table 11.4-2
$S_{DS} =$	1.200 g	Design spectral response acceleration parameter	11.4-3
$S_{D1} =$	0.680 g	Design spectral response acceleration parameter	11.4-4
Seismic Design Category:	D		Section 11.6
Building System, N-S:	A. BEARING WALL SYSTEMS	15. Light-framed (wood) walls sheathed with wood structural panels rated for shear resistance	Table 12.2-1
Building System, E-W:	A. BEARING WALL SYSTEMS	15. Light-framed (wood) walls sheathed with wood structural panels rated for shear resistance	Table 12.2-1
Diaphragm=	Flexible Diaphragm	Plywood Sheathing	
$\rho_{(N-S)} =$	1.0	Redundancy factor, N-S	12.3.4
$\rho_{(E-W)} =$	1.0	Redundancy factor, E-W	12.3.4
$R_{(N-S)} =$	6.50	Response modification coefficient, N-S	Table 12.2-1
$R_{(E-W)} =$	6.50	Response modification coefficient, E-W	Table 12.2-1
$\Omega_{o(N-S)} =$	2.50	Overstrength factor, N-S	Table 12.2-1
$\Omega_{o(E-W)} =$	2.50	Overstrength factor, E-W	Table 12.2-1
$C_{d(N-S)} =$	4.00	Deflection amplification factor, N-S	Table 12.2-1
$C_{d(E-W)} =$	4.00	Deflection amplification factor, E-W	Table 12.2-1
$T_{(N-S)} =$	0.121 sec	Approximate Fundamental Period, N-S	Section 12.8.2
$T_{(E-W)} =$	0.121 sec	Approximate Fundamental Period, E-W	Section 12.8.2
$T_L =$	8 sec	Long Period Transistion Period	USGS
$V_{(N-S)} (ULT) =$	0.231 *W	Base Shear, N-S, LRFD	Section 12.8 or 12.14
$V_{(N-S)} (ASD) =$	0.162 *W	Base Shear, N-S, ASD	Section 12.8 or 12.14
$V_{(E-W)} (ULT) =$	0.231 *W	Base Shear, E-W, LRFD	Section 12.8 or 12.14
$V_{(E-W)} (ASD) =$	0.162 *W	Base Shear, E-W, LRFD	Section 12.8 or 12.14
Structural Irregularities	Horizontal: None		Table 12.3-1
	Vertical: None		Table 12.3-2

WIND DESIGN PARAMETERS

Wind Method Used:	Directional Procedure		Chapter 27
Basic Wind Speed =	98 MPH	Ultimate Design Wind Speed (3 second gust)	Figure 26.5-1A,B or C
Exposure Category:	C	Open Terrain	26.7.3
$K_{zt} =$	1.00	Topographic Factor	26.8
$K_d =$	0.85	Buildings	Table 26.6-1

ZFA STRUCTURAL ENGINEERSJob #21650
Design CriteriaEngineer: BVC; DM
1/3/2022

Davidson MS HVAC

DETAILED DESIGN CRITERIA**MATERIAL STRENGTH AND SPECIFICATIONS****STEEL CONNECTORS:**

Shear stud connectors, $f_u =$	65 ksi	ASTM A108
Machine Bolts, $f_u =$	58 ksi	ASTM A307
High Strength Bolts, $f_u =$	120 ksi	ASTM A325
Anchor Bolts, $f_y =$	36 ksi	ASTM F1554, Grade 36 or ASTM A307
Anchor Bolts, $f_u =$	58 ksi	ASTM F1554, Grade 36 or ASTM A307
Threaded Rods, $f_y =$	36 ksi	ASTM F1554, Grade 36 or ASTM A307
Threaded Rods, $f_u =$	58 ksi	ASTM F1554, Grade 36 or ASTM A307
Weld, $F_{EXX} =$	70 ksi	Weld Strength

WOOD CONSTRUCTION:

6x Posts, $F_b =$	1200 psi	Douglas Fir #1
6x Beam, $F_b =$	1350 psi	Douglas Fir #1
4x Posts & Beams, $F_b =$	1000 psi	Douglas Fir #1
2x Joists & Rafters, $F_b =$	900 psi	Douglas Fir #2
2x Studs, $F_b =$	900 psi	Douglas Fir #2
Sheathing	PS1 / PS2	
Connections	Simpson Strong-Tie	
Glued-Laminated Beam (GLB), $F_b =$	2400 psi	24F-V4 (DF/DF) simple span, 24F-V8 (DF/DF) continuous span
Exterior GLB, $F_b =$	2000 psi	20F-V12 (AC/AC) simple span, 20F-V13 (AC/AC) continuous span
Parallel Strand Lumber (PSL), $F_b =$	2900 psi	Grade 2.0E
Laminated Veneer Lumber (LVL), $F_b =$	2600 psi	Grade 1.9E
Laminated Strand Lumber (LSL), $F_b =$	1700 psi	Grade 1.3E



Search Information

Address: 280 Woodland Avenue San Rafael, California 94901
Coordinates: 37.965895, -122.524903
Elevation: 7 ft
Timestamp: 2021-01-26T23:46:02.257Z
Hazard Type: Seismic
Reference Document: ASCE7-16
Risk Category: III
Site Class: D-default



Basic Parameters

Name	Value	Description
S _S	1.5	MCE _R ground motion (period=0.2s)
S ₁	0.6	MCE _R ground motion (period=1.0s)
S _{MS}	1.8	Site-modified spectral acceleration value
S _{M1}	* null	Site-modified spectral acceleration value
S _{DS}	1.2	Numeric seismic design value at 0.2s SA
S _{D1}	* null	Numeric seismic design value at 1.0s SA

* See Section 11.4.8

Additional Information

Name	Value	Description
SDC	* null	Seismic design category
F _a	1.2	Site amplification factor at 0.2s
F _v	* null	Site amplification factor at 1.0s
CR _S	0.921	Coefficient of risk (0.2s)
CR ₁	0.906	Coefficient of risk (1.0s)
PGA	0.523	MCE _G peak ground acceleration
F _{PGA}	1.2	Site amplification factor at PGA
PGA _M	0.627	Site modified peak ground acceleration
T _L	12	Long-period transition period (s)
SsRT	1.733	Probabilistic risk-targeted ground motion (0.2s)
SsUH	1.881	Factored uniform-hazard spectral acceleration (2% probability of exceedance in 50 years)

SsD	1.5	Factored deterministic acceleration value (0.2s)
S1RT	0.687	Probabilistic risk-targeted ground motion (1.0s)
S1UH	0.758	Factored uniform-hazard spectral acceleration (2% probability of exceedance in 50 years)
S1D	0.6	Factored deterministic acceleration value (1.0s)
PGAd	0.523	Factored deterministic acceleration value (PGA)

Page 9

* See Section 11.4.8

The results indicated here DO NOT reflect any state or local amendments to the values or any delineation lines made during the building code adoption process. Users should confirm any output obtained from this tool with the local Authority Having Jurisdiction before proceeding with design.

Disclaimer

Hazard loads are provided by the U.S. Geological Survey [Seismic Design Web Services](#).

While the information presented on this website is believed to be correct, ATC and its sponsors and contributors assume no responsibility or liability for its accuracy. The material presented in the report should not be used or relied upon for any specific application without competent examination and verification of its accuracy, suitability and applicability by engineers or other licensed professionals. ATC does not intend that the use of this information replace the sound judgment of such competent professionals, having experience and knowledge in the field of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the results of the report provided by this website. Users of the information from this website assume all liability arising from such use. Use of the output of this website does not imply approval by the governing building code bodies responsible for building code approval and interpretation for the building site described by latitude/longitude location in the report.



Search Information

Address: 280 Woodland Avenue San Rafael, California 94901
Coordinates: 37.965895, -122.524903
Elevation: 7 ft
Timestamp: 2021-01-26T23:46:55.686Z
Hazard Type: Wind



ASCE 7-16

MRI 10-Year 63 mph
 MRI 25-Year 70 mph
 MRI 50-Year 74 mph
 MRI 100-Year 78 mph
 Risk Category I 86 mph
 Risk Category II 91 mph
 Risk Category III 98 mph
 Risk Category IV 102 mph

ASCE 7-10

MRI 10-Year 72 mph
 MRI 25-Year 79 mph
 MRI 50-Year 85 mph
 MRI 100-Year 91 mph
 Risk Category I 100 mph
 Risk Category II 110 mph
 Risk Category III-IV 115 mph

ASCE 7-05

ASCE 7-05 Wind Speed 85 mph

The results indicated here DO NOT reflect any state or local amendments to the values or any delineation lines made during the building code adoption process. Users should confirm any output obtained from this tool with the local Authority Having Jurisdiction before proceeding with design.

Disclaimer

Hazard loads are interpolated from data provided in ASCE 7 and rounded up to the nearest whole integer. Per ASCE 7, islands and coastal areas outside the last contour should use the last wind speed contour of the coastal area – in some cases, this website will extrapolate past the last wind speed contour and therefore, provide a wind speed that is slightly higher. NOTE: For queries near wind-borne debris region boundaries, the resulting determination is sensitive to rounding which may affect whether or not it is considered to be within a wind-borne debris region.

Mountainous terrain, gorges, ocean promontories, and special wind regions shall be examined for unusual wind conditions.

While the information presented on this website is believed to be correct, ATC and its sponsors and contributors assume no responsibility or liability for its accuracy. The material presented in the report should not be used or relied upon for any specific application without competent examination and verification of its accuracy, suitability and applicability by engineers or other licensed professionals. ATC does not intend that the use of this information replace the sound judgment of such competent professionals, having experience and knowledge in the field of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the results of the report provided by this website. Users of the information from this website assume all liability arising from such use. Use of the output of this website does not imply approval by the governing building code bodies responsible for building code approval and interpretation for the building site described by latitude/longitude location in the report.

ZFA STRUCTURAL ENGINEERSJob #21650
Flat WeightsEngineer: BVC; DM
1/3/2022

Davidson MS HVAC

GRAVITY / SEISMIC FLAT WEIGHT TAKEOFF (PSF)**FLAT ROOF @ ANNEX**

CBC Live Load Category: 26. Roof: ordinary

[Table 1607.1]

Slope: 0.00:12

Balcony?: No

Material	Thickness (in)	Sloped	Deck	Joists	Girders	Columns	Seismic
Roofing: Cap Sheet			3.0	3.0	3.0	3.0	3.0
Sheathing: 1/2 in. OSB			1.7	1.7	1.7	1.7	1.7
Decking: Leveling Lightweight Conc t =	1.5		15.0	15.0	15.0	15.0	15.0
Insulation: "Soft": Loose Fill, Blown-In, & Batt t =	3		0.6	0.6	0.6	0.6	0.6
Ceiling: 1/2 in. Gypsum Board				2.2	2.2	2.2	2.2
Framing:				0.0	0.0	0.0	0.0
Framing: DF-L 3x12 @ 16"oc					5.5	5.5	5.5
Framing:						0.0	0.0
MEP:			0.0	0.0	0.0	0.0	0.0
MEP: Typical			2.0	2.0	2.0	2.0	2.0
MEP: Solar			3.0	3.0	3.0	3.0	3.0
Miscellaneous			1.5	1.5	1.5	1.5	1.5
Dead Load			26.8	29.0	34.5	34.5	34.5
Dead Load - Horiz Projection			26.8	29.0	34.5	34.5	34.5
Partitions (Office Buildings)		No	0.0	0.0	0.0	0.0	0.0
Live Load			20.0	20.0	20.0	20.0	0.0
Live Load - Reduced R ₂ =	1.00		20.0	20.0	20.0	20.0	0.0
Total Load			46.8	49.0	54.5	54.5	34.5

2:12 ROOF @ SHOP BLDG

CBC Live Load Category: 26. Roof: ordinary

[Table 1607.1]

Slope: 2.00:12

Balcony?: No

Material	Thickness (in)	Sloped	Deck	Joists	Girders	Columns	Seismic
Roofing: Cap Sheet		Yes	3.0	3.0	3.0	3.0	3.0
Sheathing: 1/2 in. OSB		Yes	1.7	1.7	1.7	1.7	1.7
Decking:			0.0	0.0	0.0	0.0	0.0
Insulation: "Soft": Loose Fill, Blown-In, & Batt t =	2	Yes	0.4	0.4	0.4	0.4	0.4
Ceiling: Acoustical Fiber Tile		Yes		1.0	1.0	1.0	1.0
Framing: DF-L 2x6 @ 24"oc				1.1	1.1	1.1	1.1
Framing: GLB BEAMS					1.7	1.7	1.7
Framing: GLB GIRDER						1.0	1.0
MEP:			0.0	0.0	0.0	0.0	0.0
MEP: Typical			2.0	2.0	2.0	2.0	2.0
MEP: Solar			3.0	3.0	3.0	3.0	3.0
Miscellaneous			1.8	1.7	2.0	2.0	2.0
Dead Load			11.9	13.9	15.9	16.9	16.9
Dead Load - Horiz Projection			12.0	14.0	16.0	17.0	17.0
Partitions (Office Buildings)		No	0.0	0.0	0.0	0.0	0.0
Live Load			20.0	20.0	20.0	20.0	0.0
Live Load - Reduced R ₂ =	1.00		20.0	20.0	20.0	20.0	0.0
Total Load			32.0	34.0	36.0	37.0	17.0


SHEAR WALL CAPACITY CHECK AT ANNEX

This calculation checks the reduced capacity of an (E) shear wall at the annex due to a widened louver opening.

Opening location:



Existing shear wall (length of wall is approximate):



Check shear wall:

Wall length = 24.0 ft (conservative)

Existing:

(E) OPNG = 24 in
(E) effective SW length = 22.0 ft

New:

(N) OPNG = 26 in
(N) effective SW length = 21.8 ft

Conclude:

Reduction in length = 0.2 ft
% reduction of original = 0.69 % < 5% ? (for CAC check)

PER CAC 4-309, DOES NOT EXCEED 5% RULE

ANCHORAGE

The following calculations check anchorage for a wall-mounted electrical panel and various pieces of mechanical equipment.

ZFA STRUCTURAL ENGINEERS

Job #21650
Wall-Mounted Electrical Panel

Engineer: BVC; DM
1/3/2022

Davidson MS HVAC

WALL-MOUNTED ELECTRICAL PANEL

CBC2019, ASCE 7-16 CHAPTER 11, 12, 13 SEISMIC DESIGN CRITERIA

Soil Site Class: **D (by default)** Table 20.3-1
 Response Spectral Acc. (0.2 sec) $S_s = 1.500g = 150.00\%g$ Figure 22-1, 22-3, 22-5, and 22-6
 Response Spectral Acc. (1.0 sec) $S_1 = 0.600g = 60.00\%g$ Figure 22-2, 22-4, 22-5, and 22-6
 Site Coefficient $F_a = 1.200$ Table 11.4-1
 Site Coefficient $F_v = 1.7$ Table 11.4-2
 Max Considered Earthquake Acc. $S_{MS} = F_a S_s = 1.800$ (11.4-1)
 Max Considered Earthquake Acc. $S_{M1} = F_v S_1 = 1.020$ (11.4-2)
 @ 5% Damped Design $S_{DS} = 2/3(S_{MS}) = 1.200$ (11.4-3)
 $S_{D1} = 2/3(S_{M1}) = 0.680$ (11.4-4)
 Building Risk Categories: **III Public hazard** Table 1.5-1
Design Category Consideration: **III Flexible Diaphragm** with dist. between seismic resisting system >40ft
 Seismic Design Category for 0.1sec: **D**
 Seismic Design Category for 1.0sec: **D**
 $S_1 < .75g$ **NA**
Comply with Seismic Design Category D

13.3 Seismic Demands on Nonstructural Components

Component Name: Wall-Mounted Electrical Panel "LAA"
Component Description: Motor control centers, panel boards, switch gear, instrumentation cabinets, and other components constructed of sheet metal framing

$$F_p = \frac{0.4a_p S_{DS} W_p (1+2z/h)}{(R_p/I_p)} \quad S_{DS} = 1.200 \quad (13.3-1)$$

$a_p = 2.5$ $R_p = 6.0$ T-13.5-1 or 13.6-1
 $\Omega_p = 2.0$ T-13.5-1 or 13.6-1
 $I_p = 1.0$ 13.1.3

z (assumed) = **4 ft** $h = 11$ ft $F_p = 0.345 W_p$
 Max $F_p = 1.6 S_{DS} I_p W_p = 1.920 W_p$ (13.3-2)
 Min $F_p = 0.3 S_{DS} I_p W_p = 0.360 W_p$ (13.3-3)
 $F_p = 0.360 W_p$
 F_p Anchorage to Concrete IF using $\Omega_p = 0.720 W_p$ (not reqd since on wood SW) T-13.5-1 footnote b or 13.6-1 footnote c

NOTE: $W_{panel} = 87$ lbs (DL)
 $F_{p,LRFD} = 31$ lbs
 $F_{p,ASD} = 22$ lbs

Incorporate Horizontal & Vertical Seismic Forces (ASD):

$E_h = 22$ lbs (EQ 12.4-3)
 $E_v = 21$ lbs (EQ 12.4-4a)

using ASD load combinations:
 $Load_3 = 117$ lbs (2.4.5(8))
 $Load_9 = 109$ lbs (2.4.5(9))
 $Load_{10} = 53$ lbs (2.4.5(10))

total applied panel load (TAPL) = 117 lbs GOVERNS

Check Hardware Capacity < TAPL:

Capacity_{A34} = 395 lb (see SST screenshot below)
 Capacity_{#14 wood screw} = 160 lb (see NDS calc screenshot below)

CONCLUDE: capacity of a single #14 wood screw / single A34 > applied panel load... OKAY

Member No.	Type of Connector	Fastener Size	Direction of Load	NDS Allowable Loads			Service Allowable Loads			Side Note
				Parallel to Grain	Perp. to Grain	Edge	Parallel to Grain	Perp. to Grain	Edge	
13	Ø10 x 1 1/4	F _p	F _p	495	495	495	345	495	495	20% 13.1.4
				385	495	495	315	495	495	
				495	495	495	315	495	495	
				495	495	495	315	495	495	
13	Ø14 x 1 3/8	F _p	F _p	645	645	645	450	645	645	
				500	645	645	375	645	645	
				645	645	645	375	645	645	
				645	645	645	375	645	645	

Connection Calculator

Design Method: Allowable Stress Design (ASD)
 Connection Type: Lateral loading
 Fastener Type: Wood Screw
 Loading Scenario: Single Shear

Main Member Type: Douglas Fir-Larch
 Main Member Thickness: 5.5 in.
 Main Member: Angle of Load to Grain: 90
 Side Member Type: Plywood (other grades)
 Side Member Thickness: 3/8 in.
 Side Member: Angle of Load to Grain: 0
 Wood Screw Number: 14 (Ø = 0.242 in.)
 Length: 8 in.
 Load Duration Factor: C_D = 1.6
 Wet Service Factor: C_W = 1.0
 End Grain Factor: C_{eg} = 1.0
 Temperature Factor: C_t = 1.0

Connection Yield Modes

Ia	2149 lbs.
Ib	160 lbs.
II	720 lbs.
IIIa	649 lbs.
IIIb	165 lbs.
IV	238 lbs.

Adjusted ASD Capacity: 160 lbs.

- Wood Screw bending yield strength of 70000 psi is assumed.
- Dowel bearing strengths for wood screws with nominal diameter greater than 1/4 in. are calculated and rounded to the nearest 50 psi in accordance with NDS Table 11.3.2.
- Length of tapered tip is assumed to be two times the nominal wood screw diameter for calculating dowel bearing length in the main member.

While every effort has been made to insure the accuracy of the information presented, and special effort has been made to assure that the information reflects the state-of-the-art, neither the American Wood Council nor its members assume any responsibility for any particular design prepared from this on-line Connection Calculator. Those using this on-line Connection Calculator assume all liability from its use.

The Connection Calculator was designed and created by Cameron Knudson, Michael Dodson and David Pollock at Washington State University. Support for development of the Connection Calculator was provided by [American Wood Council](#).

Vert Fan Coil

Calculation checks worst loading case for vertical fan coils, using information from A/M-4.1

ZFA STRUCTURAL ENGINEERS

Job #21650
Vert FC - Fp

Engineer: BVC; DM
1/3/2022

Davidson MS HVAC

VERTICAL FAN COIL (167 lb)

CBC2019, ASCE 7-16 CHAPTER 11, 12, 13 SEISMIC DESIGN CRITERIA

Soil Site Class	D (by default)	Table 20.3-1	
Response Spectral Acc. (0.2 sec) S_s	1.500g	= 150.00%g	Figure 22-1, 22-3, 22-5, and 22-6
Response Spectral Acc. (1.0 sec) S_1	0.600g	= 60.00%g	Figure 22-2, 22-4, 22-5, and 22-6
Site Coefficient F_a	1.200		Table 11.4-1
Site Coefficient F_v		1.7	Table 11.4-2
Max Considered Earthquake Acc. $S_{MS} = F_a \cdot S_s$		= 1.800	(11.4-1)
Max Considered Earthquake Acc. $S_{M1} = F_v \cdot S_1$		= 1.020	(11.4-2)
@ 5% Damped Design $S_{DS} = 2/3(S_{MS})$		= 1.200	(11.4-3)
$S_{D1} = 2/3(S_{M1})$		= 0.680	(11.4-4)
Building Risk Categories	III	Public hazard	Table 1.5-1
Design Category Consideration:	Flexible Diaphragm	with dist. between seismic resisting system >40ft	
Seismic Design Category for 0.1sec	D		
Seismic Design Category for 1.0sec	D		
$S_1 < .75g$	NA		

Comply with Seismic Design Category D

13.3 Seismic Demands on Nonstructural Components

Component Name: Vertical Fan Coil FC 27-1

Component Description: Air coolers (fin fans), air-cooled heat exchangers, condensing units, dry coolers, remote radiators and other mechanical components elevated on integral structural steel or sheet metal supports

$$F_p = \frac{0.4a_p S_{DS} W_p (1+2z/h)}{(R_p/I_p)} \quad S_{DS} = 1.200 \quad (13.3-1)$$

$a_p = 2.5$ $R_p = 3.0$ T-13.5-1 or 13.6-1
 $\Omega_o = 1.5$ T-13.5-1 or 13.6-1
 $I_p = 1.0$ 13.1.3
 $z = 4 \text{ ft}$ $h = 11 \text{ ft}$ $F_p = 0.691 W_p$

Max $F_p = 1.6 S_{DS} I_p W_p = 1.920 W_p$ (13.3-2)
 Min $F_p = 0.3 S_{DS} I_p W_p = 0.360 W_p$ (13.3-3)
 $F_p = 0.691 W_p$
 F_p Anchorage to Concrete IF using $\Omega_o = 1.036 W_p$ T-13.5-1 footnote b or 13.6-1 footnote c

$W_p = 167.0$ lb
 $F_p = 115.4$ lb (LRFD)
 F_p Anchorage to Concrete IF using $\Omega_o = 173.1$ lb

ZFA STRUCTURAL ENGINEERS

Job #21650
Vert FC - Anchorage

Engineer: BVC; DM
1/3/2022

Davidson MS HVAC

VERTICAL FAN COIL ANCHORAGE

Calculations for detail A/M-4.1... use identical anchorage for C/M-4.1 and D/M-4.1 since A/M-4.1 has the heaviest unit. See also "Vert Fan Coil Fp" calc.

Fan coil weight = 167 lb (FC 27-1 from MECH drawings)

From "Vert Fan Coil Fp" sheet:

$F_{p, LRFD} = 115$ lb
 $F_{p, ASD} = 80.8$ lb

Incorporate Horizontal & Vertical Seismic Forces (ASD):

$E_h = 81$ lbs (EQ 12.4-3)
 $E_v = 40$ lbs (EQ 12.4-4a)

using ASD load combinations:

$Load_8 = 252$ lbs (2.4.5(8))
 $Load_9 = 230$ lbs (2.4.5(9))
 $Load_{10} = 129$ lbs (2.4.5(10))

total load (TL) = 252 lbs GOVERNS

Seismic strap fasteners:

Lag screws: quantity = 4
load/fastener = 62.9 lb (ASD) *use for tension and shear load*
dia = 0.38 in (from mech detail)
embed = 2.5 in (from mech detail)

check shear...

check using AWC connection calculator:

fastener capacity = 327 lb (ASD)

CONCLUDE:
DCR = 0.19
shear OK

Design Method	Allowable Stress Design (ASD)
Connection Type	Lateral loading
Fastener Type	Lag Screw
Loading Scenario	Single Shear
Main Member Type	Douglas Fir-Larch
Main Member Thickness	3.5 in.
Main Member: Angle of Load to Grain	0
Side Member Type	Steel
Side Member Thickness	12 gage
Side Member: Angle of Load to Grain	0
Washer Thickness	0 in.
Nominal Diameter	3/8 in.
Length	2.5 in.
Load Duration Factor	C _D = 1.6
Wet Service Factor	C _M = 1.0
End Grain Factor	C _{eg} = 1.0
Temperature Factor	C _t = 1.0

Connection Yield Modes

I _m	1292 lbs.
I _s	688 lbs.
II	580 lbs.
III _m	695 lbs.
III _s	527 lbs.
IV	436 lbs.

Adjusted ASD Capacity 327 lbs.

ZFA STRUCTURAL ENGINEERS

Job #21650
Vert FC - Anchorage

Engineer: BVC; DM
1/3/2022

Davidson MS HVAC

check tension...

check using AWC connection calculator:

fastener capacity = 747 lb (ASD)

CONCLUDE:
DCR = 0.08
tension OK

Design Method	Allowable Stress Design (ASD)
Connection Type	Withdrawal loading
Fastener Type	Lag Screw
Loading Scenario	N/A
Main Member Type	Douglas Fir-Larch
Main Member Thickness	3.5 in.
Side Member Type	Steel
Side Member Thickness	1/2 gage
Washer Thickness	0 in.
Nominal Diameter	3/8 in.
Length	2.5 in.
Load Duration Factor	C _D = 1.6
Wet Service Factor	C _M = 1.0
End Grain Factor	C _{eg} = 1.0
Temperature Factor	C _t = 1.0

Adjusted ASD Capacity 747 lbs.

CONCLUDE:
USE... 0.38 dia 2.5 embed (inches)


Machine bolts: quantity = 4
load/fastener = 62.9 lb (ASD) *use for tension and shear load*
dia = 0.38 in (from mech detail)
embed = 0 in (from mech detail)

NOTE: conservatively apply "load/fastener" as shear & tension to MB for combined check

shear & tension checks on "Vert FC - MB Check" sheet

CONCLUDE:
USE... 0.38 dia 0 embed (inches)

Screws:



worst loading case shown to left

quantity in shear = 4
load/fastener in shear = 62.9 lb (ASD)
quantity in tension = 2
load/fastener in tension = 126 lb (ASD)
dia = 0.19 in (from mech detail)
material gauge = 10 g (from mech detail)

CONCLUDE:
USE... #10 screws

ZFA STRUCTURAL ENGINEERSJob #21650
Vert FC - MB CheckEngineer: BVC; DM
1/3/2022

Davidson MS HVAC

VERTICAL FAN COIL BOLT CAPACITYLoading: **MACHINE BOLT - VERT FAN COIL ANCHORAGE**

see also: "Vert Fan Coil Anchorage" sheet

Design Methodology	ASD
Shear Demand	V = 0.1 k
Tension Demand	T = 0.1 k

Design Strength (§J3.6 & §J3.7): $\Omega = 2.00$

Bolt Description **A307**
 Nominal Tensile Stress $F_{nt} = 45$ ksi
 Nominal Shear Stress $F_{nv} = 27$ ksi
 Bolt Diameter $d = 0.38$ in
 Bolt Area $A_b = 0.11$ in²

Allowable Shear Strength	$F_{nv} A_b / \Omega = 1.5$ k
Shear Utilization Ratio	DCR = 0.04

Required Shear Stress $f_{rv} = 0.6$ ksi
 Modified Tensile Stress $F_{nt}' = \min[F_{nt}, 1.3 F_{nt} - (\Omega F_{nt} / F_{nv}) f_{rv}] = 45.0$ ksi

Available Tensile Strength	$F_{nt}' A_b / \Omega = 2.5$ k
Tension Utilization Ratio	DCR = 0.03

Design Bearing Strength (§J3.10): $\Omega = 2.00$

Minimum Tensile Strength of Connected Material $F_u = 50$ ksi
 Clear Distance from Hole to Hole or Edge $l_c = 0.81$ in
 Thickness of Connected Material $t = 0.06$ in

Bearing Condition **Deformation at bolt hole at service load is considered**
 Nominal Bearing Strength $R_n = \min[1.2 l_c t F_u, 2.4 d t F_u] = 2.8$ k

Available Bearing Strength	$R_n / \Omega = 1.4$ k
Bearing Utilization Ratio	DCR = 0.04

ZFA STRUCTURAL ENGINEERS

Job #21650

Vert FC - Screw Check

Engineer: BVC; DM

1/3/2022

Davidson MS HVAC

VERTICAL FAN COIL SCREW CAPACITYReference: [AISI S100-16](#) Section J4Applies to $0.08 \leq d \leq 0.25$

See Section I2 for diaphragms

Minimum spacing between fastener centers = 3d

Minimum edge distance to fastener center = 1.5d

SMS #10

d 0.19 in Nominal screw diameter

Mils	Gauge	Thickness
18	25	0.0188
27	22	0.0283
30	20	0.0312
33	20	0.0346
43	18	0.0451
54	16	0.0566
68	14	0.0713
97	12	0.1017
118	10	0.1242

Member in contact with screw head

Mils 118

Grade 50 Conforming to A3.1.1

 $t_1 = 0.124$ in $F_{y1} = 50$ ksi $F_{u1} = 65$ ksi**Member not in contact with screw head**

Mils 118

Grade 50 Conforming to A3.1.1

 $t_2 = 0.124$ in $F_{y2} = 50$ ksi $F_{u2} = 65$ ksi**Demands to Screw** $V_{max} = 0.063$ kips ASD Load Input $T_{max} = 0.126$ kips**Shear Strength of Screw Connection (per Section J4.3)** $t_2/t_1 = 1.00$ $P_{nv1} = 4.2 (t_2^3 d)^{1/2} F_{u2} = 5.209$ kips (Eq J4.3.1-1) $P_{nv2} = 2.7 t_1 d F_{u1} = 4.141$ kips (Eq J4.3.1-2), (Eq J4.3.1-4) $P_{nv3} = 2.7 t_2 d F_{u2} = 4.141$ kips (Eq J4.3.1-3), (Eq J4.3.1-5) $P_{nv,min,1} = \min(P_{nv1}, P_{nv2}, P_{nv3}) = 4.141$ kips for $t_2/t_1 \leq 1.0$ $P_{nv,min,2} = \min(P_{nv2}, P_{nv3}) = 4.141$ kips for $t_2/t_1 \geq 2.5$ $P_{nv} = 4.141$ kips Shear resistance of sheet $P_{nvs} = 1.644$ kips Shear resistance of screw**Tension Strength of Screw Connection (per Section J4.4)** $d_h = 0.340$ in Screw head diameter $d_w = 0.000$ in Steel washer diameter (5/16" min) $t_w = 0.000$ in Steel washer thickness $d'_w = 0.340$ in (J4.4.2-2), J4.4.2 (a), (b), (c) $t_c = 0.124$ in assume full penetration of t_2 $P_{not} = 0.85 t_c d F_{u2} = 1.304$ kips (J4.4.1-1) $P_{nov} = 1.5 t_1 d'_w F_{u1} = 4.117$ kips (J4.4.2-1) $P_{nts} = 1.158$ kips Tension resistance of screw

Ω	3.00	J4.3.2	ASD
P_{nv}/Ω	0.548	kips	
DCR	0.11		

Ω	3.00	J4.4.3	ASD
P_{nts}/Ω	0.386	kips	
DCR	0.33		

ZFA STRUCTURAL ENGINEERS

Job #21650

Vert FC - Screw Check

Engineer: BVC; DM

1/3/2022

Davidson MS HVAC

Combined Shear and Pull-Over Screw Connection (per Section J4.5.1)

$$\frac{\bar{V}}{P_{nv}} + 0.71 \frac{\bar{T}}{P_{nov}} \leq \frac{1.10}{\Omega} \quad (ASD) \quad (Eq. J4.5.1-1a)$$

$$\frac{\bar{V}}{P_{nv}} + 0.71 \frac{\bar{T}}{P_{nov}} \leq 1.10\phi \quad (LRFD, LSD) \quad (Eq. J4.5.1-1b)$$

$$P_{nv} = 4.14 \text{ kips}$$

$$P_{nov} = 4.12 \text{ kips}$$

$$V/P_{nv} = 0.02$$

$$T/P_{nov} = 0.03$$

	Ω	2.35	J4.5.1	ASD
	$1.10/\Omega =$	0.468		
Stress Ratio =		0.037		
DCR =		0.08		

Combined Shear and Pull-Out Screw Connection (per Section J4.5.2)

$$\frac{\bar{V}}{P_{nv}} + \frac{\bar{T}}{P_{not}} \leq \frac{1.15}{\Omega} \quad (ASD) \quad (Eq. J4.5.2-1a)$$

$$\frac{\bar{V}}{P_{nv}} + \frac{\bar{T}}{P_{not}} \leq 1.15\phi \quad (LRFD, LSD) \quad (Eq. J4.5.2-1b)$$

$$P_{nv} = 4.14 \text{ kips}$$

$$P_{not} = 1.30 \text{ kips}$$

$$V/P_{nv} = 0.02$$

$$T/P_{not} = 0.10$$

	Ω	2.55	J4.5.2	ASD
	$1.15/\Omega =$	0.451		
Stress Ratio =		0.112		
DCR =		0.25		

Combined Shear and Tension in Screw (per Section J4.5.3)

$$\frac{\bar{V}}{P_{nvs}} + \frac{\bar{T}}{P_{nts}} \leq \frac{1.3}{\Omega} \quad (ASD) \quad (Eq. J4.5.3-1a)$$

$$\frac{\bar{V}}{P_{nvs}} + \frac{\bar{T}}{P_{nts}} \leq 1.3\phi \quad (LRFD, LSD) \quad (Eq. J4.5.3-1b)$$

$$P_{nvs} = 1.64 \text{ kips}$$

$$P_{nts} = 1.16 \text{ kips}$$

$$V/P_{nvs} = 0.04$$

$$T/P_{nts} = 0.11$$

	Ω	3.00	J4.5.3	ASD
	$1.3/\Omega =$	0.433		
Stress Ratio =		0.147		
DCR =		0.34		

Horiz Fan Coil

Calculation checks worst loading case for horizontal fan coils, using information from B/M-4.1 and the associated detail D/M-4.3

ZFA STRUCTURAL ENGINEERS

Job #21650
 Horiz FC - Fp

Engineer: BVC; DM
 1/3/2022

Davidson MS HVAC

HORIZONTAL FAN COIL (167 lb)

CBC2019, ASCE 7-16 CHAPTER 11, 12, 13 SEISMIC DESIGN CRITERIA

Soil Site Class	D (by default)	Table 20.3-1	
Response Spectral Acc. (0.2 sec) S_s	1.500g	= 150.00%g	Figure 22-1, 22-3, 22-5, and 22-6
Response Spectral Acc. (1.0 sec) S_1	0.600g	= 60.00%g	Figure 22-2, 22-4, 22-5, and 22-6
Site Coefficient F_a	1.200		Table 11.4-1
Site Coefficient F_v		1.7	Table 11.4-2
Max Considered Earthquake Acc. $S_{MS} = F_a \cdot S_s$		= 1.800	(11.4-1)
Max Considered Earthquake Acc. $S_{M1} = F_v \cdot S_1$		= 1.020	(11.4-2)
@ 5% Damped Design $S_{DS} = 2/3(S_{MS})$		= 1.200	(11.4-3)
$S_{D1} = 2/3(S_{M1})$		= 0.680	(11.4-4)
Building Risk Categories	III	Public hazard	Table 1.5-1
Design Category Consideration:	Flexible Diaphragm	with dist. between seismic resisting system >40ft	
Seismic Design Category for 0.1sec	D		
Seismic Design Category for 1.0sec	D		
$S_1 < .75g$	NA		

Comply with Seismic Design Category D

13.3 Seismic Demands on Nonstructural Components

Component Name: Horizontal Fan Coil FC 37-1

Component Description: Air-side HVAC, fans, air handlers, air conditioning units, cabinet heaters, air distribution boxes, and other mechanical components constructed of sheet metal framing

$$F_p = \frac{0.4a_p S_{DS} W_p (1+2z/h)}{(R_p/I_p)} \quad S_{DS} = 1.200 \quad (13.3-1)$$

$a_p = 2.5$ $R_p = 6.0$ T-13.5-1 or 13.6-1
 $\Omega_o = 2.0$ T-13.5-1 or 13.6-1
 $I_p = 1.0$ 13.1.3
 $z = 11 \text{ ft}$ $h = 11 \text{ ft}$ $F_p = 0.600 W_p$

Max $F_p = 1.6 S_{DS} I_p W_p = 1.920 W_p$ (13.3-2)
 Min $F_p = 0.3 S_{DS} I_p W_p = 0.360 W_p$ (13.3-3)

$F_p = 0.600 W_p$
 F_p Anchorage to Concrete IF using $\Omega_o = 1.200 W_p$ T-13.5-1 footnote b or 13.6-1 footnote c

$W_p = 167.0$ lb
 $F_p = 100.2$ lb (LRFD)
 F_p Anchorage to Concrete IF using $\Omega_o = 200.4$ lb

ZFA STRUCTURAL ENGINEERS

Job #21650
 Horiz FC - Anchorage

Engineer: BVC; DM
 1/3/2022

Davidson MS HVAC

VERTICAL FAN COIL ANCHORAGE

Calculations for detail B/M-4.1. See also "Horiz Fan Coil Fp" calc.

Fan coil weight = 167 lb (FC 27-1 from MECH drawings)

From "Horiz Fan Coil Fp" sheet:

$F_{p, LRFD} = 100$ lb
 $F_{p, ASD} = 70.1$ lb

Incorporate Horizontal & Vertical Seismic Forces (ASD):

$E_h = 70$ lbs (EQ 12.4-3)
 $E_v = 40$ lbs (EQ 12.4-4a)

using ASD load combinations:

Load₈ = 244 lbs (2.4.5(8))
 Load₉ = 225 lbs (2.4.5(9))
 Load₁₀ = 121 lbs (2.4.5(10))

total load (TL) = 244 lbs GOVERNS

Loading:


Vertical restraints:

quantity in tension = 12
 vertical load/restraint = 20.3 lb (ASD)
 tension in rod (vertical) = 20.3 lb
 tension in cable (1:1 slope) = 28.8 lb

Horizontal restraints:

quantity in tension = 4
 horizontal load/restraint = 61 lb (ASD)
 tension in cable (1:1 slope) = 86.3 lb

check rod for... T = 61 lb (assume no "help" from seismic bracing)
 check cable for... T = 86.3 lb



ZFA STRUCTURAL ENGINEERS

Job #21650
 Horiz FC - Anchorage

Engineer: BVC; DM
 1/3/2022

Davidson MS HVAC

Check cable:

$$\begin{aligned}
 F_y &= 33 \text{ ksi (assumed)} \\
 dia &= 0.09 \text{ in (from mech detail)} \\
 A_s &= 0.01 \text{ in (from mech detail)} \\
 \Omega_t &= 2 \text{ (rupture)} \\
 A_s F_y / \Omega_t &= 114 \text{ lb}
 \end{aligned}$$

CONCLUDE:
 USE... 0.09 dia DCR 0.76

Check vertical rod:

$$\begin{aligned}
 F_y &= 36 \text{ ksi (assumed)} \\
 dia &= 0.38 \text{ in (from mech detail)} \\
 A_s &= 0.11 \text{ in (from mech detail)} \\
 \Omega_t &= 2 \text{ (rupture)} \\
 A_s F_y / \Omega_t &= 1988 \text{ lb}
 \end{aligned}$$

CONCLUDE:
 USE... 0.38 dia DCR 0.03

Check bolt connecting rod brace to blocking:

check using AWC connection calculator:

fastener capacity = 821 lb (ASD)

CONCLUDE:
 DCR = 0.07
 shear OK

Design Method	Allowable Stress Design (ASD)
Connection Type	Lateral loading
Fastener Type	Bolt
Loading Scenario	Single Shear - Wood Main Member
Main Member Type	Douglas Fir-Larch
Main Member Thickness	3.5 in.
Main Member: Angle of Load to Grain	90
Side Member Type	Steel
Side Member Thickness	1/4 in.
Side Member: Angle of Load to Grain	0
Fastener Diameter	1/2 in.
Load Duration Factor	C _D = 1.6
Wet Service Factor	C _M = 1.0
Temperature Factor	C _t = 1.0

Connection Yield Modes

I _m	1764 lbs.
I _s	3480 lbs.
II	861 lbs.
III _m	1049 lbs.
III _s	821 lbs.
IV	955 lbs.

Adjusted ASD Capacity 821 lbs.

ZFA STRUCTURAL ENGINEERS

Job #21650
 Horiz FC - Anchorage

Engineer: BVC; DM
 1/3/2022

Davidson MS HVAC

Check angle for bending:


$L_{\text{angle}} = 2.1$ ft (approx)
 force = 122 lb (1/2 of tot since 2 angles)
 load = 58.1 plf

CODE REFERENCES

Calculations per AISC 360-16, IBC 2018, CBC 2019, ASCE 7-16
 Load Combination Set : ASCE 7-16

Material Properties

Analysis Method : Allowable Strength Design F_y : Steel Yield : 36.0 ksi
 Beam Bracing : Completely Unbraced E : Modulus : 29,000.0 ksi
 Bending Axis : Major Axis Bending



Applied Loads

Service loads entered. Load Factors will be applied for calculations.

Beam self weight NOT internally calculated and added
 Uniform Load : $E = 0.05810$ k/ft, Tributary Width = 1.0 ft, (horiz FC)

DESIGN SUMMARY

			Design OK	
Maximum Bending Stress Ratio =	0.018 : 1	Maximum Shear Stress Ratio =	0.004 : 1	
Section used for this span	L3x3x1/4	Section used for this span	L3x3x1/4	
Ma : Applied	0.022 k-ft	Va : Applied	0.04270 k	
Mn / Omega : Allowable	1.216 k-ft	Vn/Omega : Allowable	9.701 k	
Load Combination	E Only * 0.70	Load Combination	E Only * 0.70	
Location of maximum on span	1.050 ft	Location of maximum on span	0.000 ft	
Span # where maximum occurs	Span # 1	Span # where maximum occurs	Span # 1	
Maximum Deflection				
Max Downward Transient Deflection	0.000 in	Ratio =	0	<360
Max Upward Transient Deflection	0.000 in	Ratio =	0	<360
Max Downward Total Deflection	0.001 in	Ratio =	50279	>=180
Max Upward Total Deflection	0.000 in	Ratio =	0	<180

Check machine bolt connecting seismic brace to blocking:

(bolts under worst loading when FC moves horizontally in either direction)

quantity = 1 (per cable/seismic brace)
 load/fastener = 61 lb (ASD) *use for shear*
 dia = 0.38 in (from mech detail)
 embed = 3.5 in (from mech detail)

ZFA STRUCTURAL ENGINEERS

Job #21650
 Horiz FC - Anchorage

Engineer: BVC; DM
 1/3/2022

Davidson MS HVAC

check shear...

check using AWC connection calculator:

fastener capacity = 629 lb (ASD)

CONCLUDE:
 DCR = 0.1
 shear OK

Design Method	Allowable Stress Design (ASD)
Connection Type	Lateral loading
Fastener Type	Bolt
Loading Scenario	Single Shear - Wood Main Member
Main Member Type	Douglas Fir-Larch
Main Member Thickness	3.5 in.
Main Member: Angle of Load to Grain	0
Side Member Type	Steel
Side Member Thickness	12 gage
Side Member: Angle of Load to Grain	0
Fastener Diameter	3/8 in.
Load Duration Factor	C _D = 1.6
Wet Service Factor	C _M = 1.0
Temperature Factor	C _t = 1.0

Connection Yield Modes

Im	2940 lbs.
Is	974 lbs.
II	1319 lbs.
III _m	1560 lbs.
III _s	629 lbs.
IV	873 lbs.

Adjusted ASD Capacity 629 lbs.

CONCLUDE:
 USE... 0.38 dia 3.5 embed (inches)

Check seismic brace connector:

(load applied to brace connector is equivalent to cable force)

from mech dwgs:

BRACE ANGLE RANGE q	MAX ALLOWABLE FORCE PER SEISMIC BRACE ASSEMBLY, F _p
30° - 45°	270 LBS
46° - 60°	190 LBS

F_{pmax} = 190 lb (ASD)

CONCLUDE:
 by observation, seismic braces OKAY

Refrig Pipe

Calculation checks anchorage for refrigeration pipe from A/M-4.3

ZFA STRUCTURAL ENGINEERS

Job #21650
Refrig Pipe - Fp

Engineer: BVC; DM
1/3/2022

Davidson MS HVAC

REFRIGERATION PIPE SUPPORT

CBC2019, ASCE 7-16 CHAPTER 11, 12, 13 SEISMIC DESIGN CRITERIA

Soil Site Class	D (by default)	Table 20.3-1	
Response Spectral Acc. (0.2 sec) S_s	= 1.500g	= 150.00%g	Figure 22-1, 22-3, 22-5, and 22-6
Response Spectral Acc. (1.0 sec) S_1	= 0.600g	= 60.00%g	Figure 22-2, 22-4, 22-5, and 22-6
Site Coefficient F_a	= 1.200		Table 11.4-1
Site Coefficient F_v	= 1.7		Table 11.4-2
Max Considered Earthquake Acc. $S_{MS} = F_a \cdot S_s$	= 1.800		(11.4-1)
Max Considered Earthquake Acc. $S_{M1} = F_v \cdot S_1$	= 1.020		(11.4-2)
@ 5% Damped Design $S_{DS} = 2/3(S_{MS})$	= 1.200		(11.4-3)
$S_{D1} = 2/3(S_{M1})$	= 0.680		(11.4-4)
Building Risk Categories	III	Public hazard	Table 1.5-1
Design Category Consideration:	Flexible Diaphragm	with dist. between seismic resisting system >40ft	
Seismic Design Category for 0.1sec	D		
Seismic Design Category for 1.0sec	D		
$S_1 < .75g$	NA		

Comply with Seismic Design Category D

13.3 Seismic Demands on Nonstructural Components

Component Name: Refrigeration pipe along wall (CONSIDERED PER 8' SUPPORT SPCG)

Component Description: Piping and tubing not in accordance with ASME B31, including in-line components, constructed of high- or limited-deformability materials, with joints made by threading, bonding, compression couplings, or grooved couplings

$$F_p = \frac{0.4a_p S_{DS} W_p (1+2z/h)}{(R_p/I_p)} \quad S_{DS} = 1.200 \quad (13.3-1)$$

$a_p = 2.5$ $R_p = 4.5$ T-13.5-1 or 13.6-1
 $\Omega_o = 2.0$ T-13.5-1 or 13.6-1
 $I_p = 1.0$ 13.1.3
 $z = 4 \text{ ft}$ $h = 11 \text{ ft}$ $F_p = 0.461 W_p$

Max $F_p = 1.6 S_{DS} I_p W_p = 1.920 W_p$ (13.3-2)
 Min $F_p = 0.3 S_{DS} I_p W_p = 0.360 W_p$ (13.3-3)
 $F_p = 0.461 W_p$
 F_p Anchorage to Concrete IF using $\Omega_o = 0.921 W_p$ T-13.5-1 footnote b or 13.6-1 footnote c

$W_p = 160.0$ lb (assumed ~20 psf)
 $F_p = 73.7$ lb (LRFD)
 F_p Anchorage to Concrete IF using $\Omega_o = 147.4$ lb

ZFA STRUCTURAL ENGINEERS

Job #21650
Refrig Pipe - Anchorage

Engineer: BVC; DM
1/3/2022

Davidson MS HVAC

REFRIGERATION PIPE ALONG WALL

Calculations for detail A/M-4.3. See also "Refrig Pipe - Fp" calc.

pipe = 160 lb

From "Refrig Pipe Fp" sheet:

$F_{p, LRFD} = 73.7$ lb
 $F_{p, ASD} = 51.6$ lb

Incorporate Horizontal & Vertical Seismic Forces (ASD):

$E_h = 52$ lbs (EQ 12.4-3)
 $E_v = 38$ lbs (EQ 12.4-4a)

using ASD load combinations:

Load₈ = 223 lbs (2.4.5(8))
Load₉ = 207 lbs (2.4.5(9))
Load₁₀ = 105 lbs (2.4.5(10))

total load (TL) = 223 lbs GOVERNS

Seismic strap fasteners:

Lag screws: quantity = 2
load/fastener = 111 lb (ASD) *use for tension and shear load*
dia = 0.38 in (from mech detail)
embed = 2.5 in (from mech detail)

check shear...

check using AWC connection calculator:

fastener capacity = 327 lb (ASD)

CONCLUDE:
DCR = 0.34
shear OK

Design Method	Allowable Stress Design (ASD)
Connection Type	Lateral loading
Fastener Type	Lag Screw
Loading Scenario	Single Shear
Main Member Type	Douglas Fir-Larch
Main Member Thickness	3.5 in.
Main Member: Angle of Load to Grain	0
Side Member Type	Steel
Side Member Thickness	12 gage
Side Member: Angle of Load to Grain	0
Washer Thickness	0 in.
Nominal Diameter	3/8 in.
Length	2 in.
Load Duration Factor	C _D = 1.6
Wet Service Factor	C _M = 1.0
End Grain Factor	C _{eg} = 1.0
Temperature Factor	C _t = 1.0

Connection Yield Modes

Im	995 lbs.
Is	688 lbs.
II	449 lbs.
IIIm	558 lbs.
IIIs	327 lbs.
IV	436 lbs.

Adjusted ASD Capacity	327 lbs.
-----------------------	----------

ZFA STRUCTURAL ENGINEERS

Job #21650
Refrig Pipe - Anchorage

Engineer: BVC; DM
1/3/2022

Davidson MS HVAC

check tension...

check using AWC connection calculator:


fastener capacity = 625 lb (ASD)

CONCLUDE:
DCR = 0.18
tension OK

Design Method	Allowable Stress Design (ASD)
Connection Type	Withdrawal loading
Fastener Type	Lag Screw
Loading Scenario	N/A
Main Member Type	Douglas Fir-Larch
Main Member Thickness	3.5 in.
Side Member Type	Steel
Side Member Thickness	12 gage
Washer Thickness	0 in.
Nominal Diameter	3/8 in.
Length	2 in.
Load Duration Factor	C _D = 1.6
Wet Service Factor	C _M = 1.0
End Grain Factor	C _{eg} = 1.0
Temperature Factor	C _t = 1.0

Adjusted ASD Capacity 625 lbs.

CONCLUDE:
USE... 0.38 dia 2.5 embed (inches)



Small Duct Support

Calculation checks anchorage for small duct support from C/M-4.3

ZFA STRUCTURAL ENGINEERS

Job #21650
Small Duct - Fp

Engineer: BVC; DM
1/3/2022

Davidson MS HVAC

SMALL DUCT SUPPORT

CBC2019, ASCE 7-16 CHAPTER 11, 12, 13 SEISMIC DESIGN CRITERIA

Soil Site Class	D (by default)	Table 20.3-1	
Response Spectral Acc. (0.2 sec) S_s	= 1.500g	= 150.00%g	Figure 22-1, 22-3, 22-5, and 22-6
Response Spectral Acc. (1.0 sec) S_1	= 0.600g	= 60.00%g	Figure 22-2, 22-4, 22-5, and 22-6
Site Coefficient F_a	= 1.200		Table 11.4-1
Site Coefficient F_v	= 1.7		Table 11.4-2
Max Considered Earthquake Acc. $S_{MS} = F_a \cdot S_s$	= 1.800		(11.4-1)
Max Considered Earthquake Acc. $S_{M1} = F_v \cdot S_1$	= 1.020		(11.4-2)
@ 5% Damped Design $S_{DS} = 2/3(S_{MS})$	= 1.200		(11.4-3)
$S_{D1} = 2/3(S_{M1})$	= 0.680		(11.4-4)
Building Risk Categories	III	Public hazard	Table 1.5-1
Design Category Consideration:	Flexible Diaphragm	with dist. between seismic resisting system >40ft	
Seismic Design Category for 0.1sec	D		
Seismic Design Category for 1.0sec	D		
$S_1 < .75g$	NA		

Comply with Seismic Design Category D

13.3 Seismic Demands on Nonstructural Components

Component Name: Small ductwork (CONSIDERED PER 8' SUPPORT SPCG)

Component Description: Ductwork, including in-line components, constructed of high- or limited-deformability materials with joints made by means other than welding or brazing

$$F_p = \frac{0.4a_p S_{DS} W_p (1+2z/h)}{(R_p/I_p)} \quad S_{DS} = 1.200 \quad (13.3-1)$$

$a_p = 2.5$ $R_p = 6.0$ T-13.5-1 or 13.6-1
 $\Omega_o = 2.0$ T-13.5-1 or 13.6-1
 $I_p = 1.0$ 13.1.3
 $z = 11 \text{ ft}$ $h = 11 \text{ ft}$ $F_p = 0.600 W_p$

Max $F_p = 1.6 S_{DS} I_p W_p = 1.920 W_p$ (13.3-2)
 Min $F_p = 0.3 S_{DS} I_p W_p = 0.360 W_p$ (13.3-3)
 $F_p = 0.600 W_p$
 F_p Anchorage to Concrete IF using $\Omega_o = 1.200 W_p$ T-13.5-1 footnote b or 13.6-1 footnote c

$W_p = 64.0$ lb (assumed 4 psf, 2 ft diameter)
 $F_p = 38.4$ lb (LRFD)
 F_p Anchorage to Concrete IF using $\Omega_o = 76.8$ lb

ZFA STRUCTURAL ENGINEERS

Job #21650
Small Duct - Anchorage

Engineer: BVC; DM
1/3/2022

Davidson MS HVAC

SMALL DUCT SUPPORT

Calculations for detail C/M-4.3. See also "Small Duct - Fp" calc.

small duct = 64 lb

From "Small Duct Fp" sheet:

$F_{p, LRFD} = 38.4$ lb
 $F_{p, ASD} = 26.9$ lb

Incorporate Horizontal & Vertical Seismic Forces (ASD):

$E_h = 27$ lbs (EQ 12.4-3)
 $E_v = 15$ lbs (EQ 12.4-4a)

using ASD load combinations:

Load₈ = 94 lbs (2.4.5(8))
Load₉ = 86 lbs (2.4.5(9))
Load₁₀ = 46 lbs (2.4.5(10))

total load (TL) = 94 lbs GOVERNS

Steel strap fasteners:

Lag screws:
quantity = 2
load/fastener = 46.8 lb (ASD) *use for shear load*
dia = 0.25 in (from mech detail)
embed = 3 in (from mech detail)

check shear...

check using AWC connection calculator:

fastener capacity = 169 lb (ASD)

CONCLUDE:
DCR = 0.28
shear OK

Design Method	Allowable Stress Design (ASD)
Connection Type	Lateral loading
Fastener Type	Lag Screw
Loading Scenario	Single Shear

Main Member Type	Douglas Fir-Larch
Main Member Thickness	3.5 in.
Main Member: Angle of Load to Grain	90
Side Member Type	Steel
Side Member Thickness	20 gage
Side Member: Angle of Load to Grain	0
Washer Thickness	0 in.
Nominal Diameter	1/4 in.
Length	3 in.
Load Duration Factor	C _D = 1.6
Wet Service Factor	C _M = 1.0
End Grain Factor	C _{eg} = 1.0
Temperature Factor	C _t = 1.0

Connection Yield Modes

Im	1310 lbs.
Is	221 lbs.
II	533 lbs.
IIIIm	547 lbs.
IIIIs	169 lbs.
IV	239 lbs.

Adjusted ASD Capacity 169 lbs.

CONCLUDE:
USE... 0.25 dia 3 embed (inches)

ZFA STRUCTURAL ENGINEERS

Job #21650

Small Duct - Anchorage

Engineer: BVC; DM

1/3/2022

Davidson MS HVAC

Check sheet metal strap:

$$\begin{aligned} F_y &= 33 \text{ ksi (assumed)} \\ l &= 2 \text{ in (from mech detail)} \\ w &= 0.01 \text{ in (assumed 28g)} \\ A_s &= 0.03 \text{ in (from mech detail)} \\ \Omega_t &= 2 \text{ (rupture)} \\ A_s F_y / \Omega_t &= 488 \text{ lb} \end{aligned}$$

CONCLUDE:**USE... 0.01 in. w DCR 0.19**

ZFA STRUCTURAL ENGINEERS

Job #21650

-----Pipe Support-----

Engineer: BVC; DM

1/3/2022

Davidson MS HVAC

Pipe Support

Calculation checks anchorage for pipe support from E/M-4.3

ZFA STRUCTURAL ENGINEERS

Job #21650
Pipe Supp - Fp

Engineer: BVC; DM
1/3/2022

Davidson MS HVAC

PIPE SUPPORT

CBC2019, ASCE 7-16 CHAPTER 11, 12, 13 SEISMIC DESIGN CRITERIA

Soil Site Class	D (by default)	Table 20.3-1	
Response Spectral Acc. (0.2 sec) S_s	= 1.500g	= 150.00%g	Figure 22-1, 22-3, 22-5, and 22-6
Response Spectral Acc. (1.0 sec) S_1	= 0.600g	= 60.00%g	Figure 22-2, 22-4, 22-5, and 22-6
Site Coefficient F_a	= 1.200		Table 11.4-1
Site Coefficient F_v	= 1.7		Table 11.4-2
Max Considered Earthquake Acc. $S_{MS} = F_a \cdot S_s$	= 1.800		(11.4-1)
Max Considered Earthquake Acc. $S_{M1} = F_v \cdot S_1$	= 1.020		(11.4-2)
@ 5% Damped Design $S_{DS} = 2/3(S_{MS})$	= 1.200		(11.4-3)
$S_{D1} = 2/3(S_{M1})$	= 0.680		(11.4-4)
Building Risk Categories	III	Public hazard	Table 1.5-1
Design Category Consideration:	Flexible Diaphragm	with dist. between seismic resisting system >40ft	
Seismic Design Category for 0.1sec	D		
Seismic Design Category for 1.0sec	D		
$S_1 < .75g$	NA		

Comply with Seismic Design Category D

13.3 Seismic Demands on Nonstructural Components

Component Name: Pipe support (CONSIDERED PER 10' SUPPORT SPCG)

Component Description: Ductwork, including in-line components, constructed of high- or limited-deformability materials with joints made by means other than welding or brazing

$$F_p = \frac{0.4a_p S_{DS} W_p (1+2z/h)}{(R_p/I_p)} \quad S_{DS} = 1.200 \quad (13.3-1)$$

$a_p = 2.5$ $R_p = 6.0$ T-13.5-1 or 13.6-1
 $\Omega_o = 2.0$ T-13.5-1 or 13.6-1
 $I_p = 1.0$ 13.1.3
 $z = 11 \text{ ft}$ $h = 11 \text{ ft}$ $F_p = 0.600 W_p$

Max $F_p = 1.6 S_{DS} I_p W_p = 1.920 W_p$ (13.3-2)
 Min $F_p = 0.3 S_{DS} I_p W_p = 0.360 W_p$ (13.3-3)

F_p Anchorage to Concrete IF using $\Omega_o = 1.200 W_p$ T-13.5-1 footnote b or 13.6-1 footnote c

$W_p = 10.0$ lb (assumed 4 psf, 3" dia pipe)
 $F_p = 6.0$ lb (LRFD)
 F_p Anchorage to Concrete IF using $\Omega_o = 12.0$ lb

ZFA STRUCTURAL ENGINEERS

Job #21650

Pipe Supp - Anchorage

Engineer: BVC; DM

1/3/2022

Davidson MS HVAC

VERTICAL FAN COIL ANCHORAGE*Calculations for detail E/M-4.3. See also "Pipe Supp Fp" calc.*

$$\text{pipe weight} = 10 \text{ lb}$$

From "Pipe Supp Fp" sheet:

$$F_{p, LRFD} = 6 \text{ lb}$$

$$F_{p, ASD} = 4.2 \text{ lb}$$

Incorporate Horizontal & Vertical Seismic Forces (ASD):

$$E_h = 4 \text{ lbs (EQ 12.4-3)}$$

$$E_v = 2 \text{ lbs (EQ 12.4-4a)}$$

using ASD load combinations:

$$\text{Load}_8 = 15 \text{ lbs (2.4.5(8))}$$

$$\text{Load}_9 = 13 \text{ lbs (2.4.5(9))}$$

$$\text{Load}_{10} = 7 \text{ lbs (2.4.5(10))}$$

$$\text{total load (TL)} = \boxed{15 \text{ lbs GOVERNS}}$$

Loading:

CONCLUDE:
by inspection, anchorage components
can withstand a load ≤ 15 lbs

