



BLDG. A - MECHANICAL 20
SCALE: 1/4" = 1'-0"

SITE PLAN - LIGHTING NORTH
SCALE: 1/16" = 1'-0"

NUMBERED SHEET NOTES

- (N) INVERTER 'INVA' SHALL BE IOTA #IIS 550 HE; 277V 1 PHASE INPUT, 277V OUTPUT RATED 550 WATTS FOR 90 MINUTES, ELECTRONICALLY FUSED OUTPUT CONNECTION TO THE LOAD, SEALED LEAD CALCIUM BATTERY, 10 YEAR LIFE. PROVIDE SEISMIC RESTRAINTS PER MFR'S INSTRUCTIONS. SURFACE MOUNT TO WALL, PER 4/E-7.1.
- (N) ASTRONOMICAL 4 ZONE TIMECLOCK 'TCA'; TORK #DZS400BP VERIFY SCHEDULES WITH OWNER.
- WALL MOUNTED OVER EXISTING LUMINAIRE LOCATION.
- SEE DETAIL 1/E-7.1.
- SEE DETAIL 2/E-7.1.
- SEE DETAIL 3/E-7.1.
- OVERRIDE SWITCHES FOR SITE LIGHTS.
- PROVIDE AN EMERGENCY LIGHTING CONTROL MODULE FOR ALL SWITCHED LIGHT FIXTURES ON EMERGENCY INVERTER OR GENERATOR. THIS INCLUDES EMERGENCY FIXTURES CONTROLLED BY OCCUPANCY SENSORS. MOUNT CONTROL MODULE/TEST SWITCH 7'-6" A.F.F. AND ALIGN WITH LIGHT SWITCH BELOW WHEREVER POSSIBLE.
- AT (E) BUILDING EXTERIOR WALL, CORE DRILL MAX. 2"Ø HOLE FOR CONDUIT IN (E) CONCRETE WALL. LOCATE (E) REINFORCING AND PROVIDE MINIMUM 1" CLEAR FROM EDGE OF CORE TO (E) REINFORCING. CONTINUE WITH CONDUIT ABOVE (E) CEILING TO ROOM MECHANICAL 20.

IDENTIFICATION STAMP
DIV. OF THE STATE ARCHITECT
APP: 01-120337 INC:
REVIEWED FOR
SS ☒ FLS ☒ ACS ☒
DATE: 2/22/2023

QUATTROCCHI KWOK ARCHITECTS
Main:
636 Fifth Street, Santa Rosa, CA 95404
East Bay:
55 Harrison Street, Suite 525,
Oakland, CA 94607
(707) 576-0829

OMAHONY & MYER
REGISTERED PROFESSIONAL ELECTRICAL ENGINEER
440 REDWOOD HWY, SUITE 245
SAN RAFAEL, CALIFORNIA 94903
(415) 490-0202 / FAX (415) 490-9603
www.omaconsulting.com

REGISTERED PROFESSIONAL ELECTRICAL ENGINEER
COLIF
P.L.L.C. No. 14738
Exp. 6/23
ELECTRICAL
STATE OF CALIFORNIA

TERRA LINDA HIGH SCHOOL
EAST PARKING LOT QUAD
320 NOVA ALBION WAY
SAN RAFAEL CA 94903

SAN RAFAEL CITY SCHOOLS

REVISIONS

DSA APP NO.	01-120337
ARCH PROJECT NO.	2003.00
DRAWN BY:	
DRAWING SCALE:	AS NOTED
PTN: 65466-44	FILE NO: 21-H1
CD	
JANUARY 18, 2023	
SHEET TITLE	

SITE PLAN - LIGHTING NORTH

SHEET NUMBER

E-101