



STRUCTURAL CALCULATIONS

Venetia Valley Elementary School Restroom Addition

SAN RAFAEL, CALIFORNIA

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>	<u>DSA Re-submittal</u>
Intent of Calculations	i.	
Description of Project	ii.	<u>✓</u>
Loads & Design Information	A1	<u>✓</u>
Gravity Framing	B1	
Lateral Framing	C1	<u>✓</u>
Foundations	D1	<u>✓</u>
Miscellaneous	E1	<u>✓</u>

Prepared for:

SVA Architects

MAY 19th, 2023





#2300173 ii.

DESCRIPTION OF PROJECT

This project includes adding a single-story restroom to the Ventia Valley elementary school in San Rafael, California.

The structure has a gable roof supported by 2x10 joists spaced at 24" o.c. A single glulam beam ridge beam is supporting the joists. The gable roof has a 5' long overhang. Roof is supported by wood stud walls along the perimeter.

Exterior wood shear walls are the main lateral force resisting system in the structure in both directions.

The structure is supported on 18" wide x 24" deep grade beams along the perimeter of the building.



A1 - LOADS & DESIGN INFORMATION

kpff Consulting Engineers 45 Fremont Street, 28th Floor San Francisco, California 94105 (415) 989-1004 FAX (415) 989-1552	Venetia Valley Restroom	by: rk	sheet no:
		date:	
	SVA		job no:
		2200173	2200173.00
			Rev. No. 120.05

DESIGN CRITERIA

Design conforms to the California Building Code, 2022 Edition.

LIVE LOADS

Roofs (flat) 20 psf

WIND ANALYSIS

Basic Wind Speed $V_{3S} = 92$ mph (ASCE 7-16 Figure 26.5)
Exposure Category = C (ASCE 7-16 Section 26.7.3)
Internal Pressure Coefficient $GC_{pi} = 0.18$ (ASCE 7-16 Table 26.13-1)

SEISMIC ANALYSIS

Static Lateral Force Procedure

Risk Category = II (ASCE 7-16 Table 1.5-1)
Site Classification = C (ASCE 7-16 Section 20.3)
Importance Factor $I_e = 1.0$ (ASCE 7-16 Table 1.5-2)

Long Direction

Long Direction Lateral System Bearing Wall: Light-frame (wood) walls sheathed with wood structural panels rated for shear resistance

Response Modifier $R = 6.5$ (ASCE 7-16 Table 12.2-1)
Overstrength Factor $\Omega_0 = 3$ (ASCE 7-16 Table 12.2-1)

Short Direction

Short Direction Lateral System Bearing Wall: Light-frame (wood) walls sheathed with wood structural panels rated for shear resistance

Response Modifier $R = 6.5$ (ASCE 7-16 Table 12.2-1)
Overstrength Factor $\Omega_0 = 3$ (ASCE 7-16 Table 12.2-1)

Site Coefficients

Short Period Spectral Acceleration $S_S = 1.500$ g
Spectral Acceleration at 1 sec. $S_1 = 0.600$ g
Short-Period Site Coefficient $F_a = 1.20$
Long-Period Site Coefficient $F_v = 1.7$

Design Parameters

Short-Period Spectral Acceleration $S_{DS} = 1.200$ g
Long-Period Spectral Acceleration $S_{D1} = 0.680$ g

Seismic Analysis Procedure: Equiv. Lateral Force Procedure (ELF) - ASCE7 Sec 12.8
Hand Calculation



Consulting Engineers
45 Fremont Street, 28th Floor
San Francisco, California 94105
(415) 989-1004 FAX (415) 989-1552

Venetia Valley Restroom

by: rk

date:

SVA

2200173

A - 2

sheet no:

job no:

2200173.00

Rev. No. 120.05

FOUNDATION CRITERIA

Reference: CBC2022 - TABLE 1806.2

AT GRADE

Maximum Soil Pressure:

Dead	1,500 psf
Dead + Live	1,500 psf
Dead + Live + Lateral	1,800 psf

Passive Earth Pressure:

Equivalent Fluid Weight	100 pcf (FS=1.5)
-------------------------	------------------

Coefficient of Friction:

0.35	(FS=1.5)
------	----------

kpf Consulting Engineers 45 Fremont Street, 28th Floor San Francisco, California 94105 (415) 989-1004 FAX (415) 989-1552	project:	Venetia Valley Restroom	by:	rk
	location:		date:	09/12/22
	client:	SVA		
				2200173.00
			Rev. No.	120.05

EQUIVALENT LATERAL FORCE PROCEDURE CBC 2022 & ASCE 7-16, Section 12.8:**Input Data:**

Risk Category =	II	(ASCE 7 Table 1.5-1)
Importance Factor, I_e =	1.00	(ASCE 7 Table 1.5-2)
Soil Site Class =	D	Default (No Soils Report) ASCE 7 Ch. 20.3 Table 20.3-1
Site Latitude & Longitude	38.001° N	-122.52484 Coordinates based on site address
Spectral Accel., S_s =	1.500	g (Geotech Report or USGS Hazard Maps)
Spectral Accel., S_1 =	0.600	g (Geotech Report or USGS Hazard Maps)
Structure Height, h_n =	13.750	ft
No. of Seismic Levels =	1	
Seismic Resist. System =	A15	ASCE Table 12.2-1
Long-Period Trans., T_L =	12	sec, ASCE7 Fig. 22-14
Fundamental Period, T =	N/A	sec, based on analysis per ASCE 12.8.2

Seismic force-resisting system = Bearing Wall: Light-frame (wood) walls sheathed with wood structural panels rated for shear resistance (ASCE Table 12.2-1)

Site Coefficients:

Ground Motion Procedure	Code Spectrum	ASCE 7 Sec 11.4.8
Short-period factor, F_a =	1.2	ASCE 7 Table 11.4-1 $F_a=1.2$ min per ASCE7 Sec 11.4.4
Long-period factor, F_v =	1.7	ASCE 7 Table 11.4-2

Maximum Spectral Response Accelerations:

S_{MS} =	1.800	$S_{MS} = F_a S_s$ (ASCE Eqn. 11.4-1)
S_{M1} =	1.020	$S_{M1} = F_v S_1$ (ASCE Eqn. 11.4-2)

Design Spectral Response Accelerations for Short and 1-Second Periods :

S_{DS} =	1.200	$S_{DS} = 2/3 S_{MS}$, ASCE Eq. 11.4-3
S_{D1} =	0.680	$S_{D1} = 2/3 S_{M1}$, ASCE Eq. 11.4-4

Calculate T_s :

T_s =	0.567	For using Code Spectrum: $T_s = S_{D1} / S_{DS}$, ASCE7 Sec 11.4.6
Governing Period, T =	0.143	sec, $T = T_a \leq T_{max}$ (ASCE 12.8.2), see calcs below
§11.4.8 to use Code Spectrum:	Site D - Period $T \leq 1.5T_s$: C_s = Eqn. 12.8-2	
Site-Specific Spectrum Exception:	Exception 2a	Code-Spectrum Permitted: ASCE7-16 Sec 11.4.8

Seismic Design Category:

Category (based on S_{DS}) =	D	ASCE Table 11.6-1
Category (based on S_{D1}) =	D	ASCE Table 11.6-2
Category ($S_1 \geq 0.75$) =	N.A.	ASCE Section 11.6
Sec 11.6 condition triggered?	No	
Seismic Design Category =	D	Governed by the most critical of all category cases above

Fundamental Period:

Period Coefficient, C_t =	0.020	ASCE Table 12.8-2 for "All other structural systems"
Period Exponent, x =	0.75	ASCE Table 12.8-2 for "All other structural systems"
Approx. Period, T_a =	0.143	sec, $T_a = C_t h_n^x$ (ASCE Eq. 12.8-7)
Upper Limit Coef., C_u =	1.400	ASCE Table 12.8-1
Period max., T_{max} =	0.200	sec, $T_{max} = C_u T_a$ (ASCE 12.8.2)
Fundamental Period, T =	0.143	sec, $T = T_a \leq T_{max}$ (ASCE 12.8.2)


Seismic Design Factors and Coefficients:

Response Modifier, R =	6.5	ASCE Table 12.2-1
Overstrength Factor, Ω_0 =	3	ASCE Table 12.2-1 (See note d for flexible diaphragms)
Defl. Amplif. Factor, C_d =	4	ASCE Table 12.2-1
C_s (Short Period) =	0.185	$C_s = S_{DS}/(R/I)$, ASCE Eq. 12.8-2, page 89
$C_s (T \leq T_L)$ =	0.733	$C_s = S_{D1}/((R/I)*T)$ for $T \leq T_L$ (ASCE Eq. 12.8-3, p. 101)
$C_s (T > T_L)$ =	N/A	$C_s = S_{D1}*T_L/((R/I)*T^2)$ for $T > T_L$ (ASCE Eq. 12.8-4, p. 101)
C_s (SSS alternate) =	N/A	$C_{s,alternate} = \text{Site-Specific } S_a/(R/I)$ per ASCE Sec 21.4
$C_{s(min)}$ =	0.053	$C_{s,min} = 0.044S_{DS}I$ or $0.5*S_1/(R/I)$ if $S_1 \geq 0.6g$ (Eq. 12.8-5&6, p. 101)
C_s (§11.4.8 exception) =	0.185	Exception 2a for Site D - Period $T \leq 1.5T_s$: C_s = Eqn. 12.8-2
Use: C_s =	0.185	$C_{s,min} \leq C_s \leq C_{s,max}$, $C \geq 0.01$

kpff Consulting Engineers 45 Fremont Street, 28th Floor San Francisco, California 94105 (415) 989-1004 FAX (415) 989-1552	project:	Venetia Valley Restroom	by:	sheet no:
	location:		rk	
	client:	SVA	date:	job no:
				2200173.00
				Rev. No. 120.05

CODE RESPONSE SPECTRUM

$S_{DS} =$	1.200	$g, S_{DS} = 2/3 S_{MS}, \text{ASCE 7 Eq. 11.4-3}$		
$S_{D1} =$	0.680	$g, S_{D1} = 2/3 S_{M1}, \text{ASCE 7 Eq. 11.4-4}$		
$T =$	0.143	sec	0.143	0
$T_0 =$	0.11	sec, $T_0 = 0.2 S_{D1}/S_{DS}, \text{ASCE 7 Section 11.4.5}$	0.143	1.200
$T_S =$	0.57	sec, $T_S = S_{D1}/S_{DS}, \text{ASCE 7 Section 11.4.5}$		
$T_L =$	12.00	sec, ASCE 7 Figure 22-16		
$S_a(T) =$	1.20	g		


Code Response Spectrum

kpff Consulting Engineers 45 Fremont Street, 28th Floor San Francisco, California 94105 (415) 989-1004 FAX (415) 989-1552	project: Venetia Valley Restroom	by:	sheet no:
	location:	rk	
	client: SVA	date:	job no:
			2200173.00
SITE-SPECIFIC RESPONSE SPECTRUM			Rev. No. 120.05

$S_{DS} = 1.200$ $g, S_{DS} = 2/3 S_{MS}, \text{ASCE 7 Eq. 11.4-3}$
 $S_{D1} = 0.680$ $g, S_{D1} = 2/3 S_{M1}, \text{ASCE 7 Eq. 11.4-4}$
 $T = 0.143$ sec
 $S_a(T) = 0.91$ g

0.143 0
0.143 1.159

Site-Specific Response Spectrum





C1 - LATERAL FRAMING

Number of seismic of Levels =	1
Total Structure Height, h_n =	13.75
Seismic Base Shear Coefficient, C_s =	0.185

W = 60	kips	(ASCE 7-16 Section 12.7.2)
W*C_s = V = 11.1	kips	LRFD
0.7*W*C_s = V = 8	kips	ASD

[illegible]

VERTICAL DISTRIBUTION OF LATERAL SEISMIC FORCE

Base Shear = 8 kips

Fundamental Period, $T = 0.143$ sec

Vertical Distribution of Seismic Forces:

Distribution Exponent, $k = 1.00$ $k = 1$ for $T \leq 0.5$ sec., $k = 2$ for $T \geq 2.5$ sec.

Linear interpolation: $k = (2-1) \cdot (T-0.5) / (2.5-0.5) + 1$, for $0.5 \text{ sec.} < k < 2.5 \text{ sec.}$

Lateral Force at Any Level: $F_x = C_{vx} * V$, ASCE 7 Eq. 12.8-11 (p. 72)

Vertical Distribution Factor: $C_{vx} = W_x \cdot h_x^k / (\sum W_i \cdot h_i^k)$, ASCE 7 Eq. 12.8-12 (p. 73)

Diaphragm Design Forces:

$$C_{px,max} = \boxed{0.480} \quad C_{px,max} = 0.4 * S_{DS} * I, \text{ ASCE 7 Eq. 12.10-3 (p. 75)}$$
$$C_{px,min} = 0.240 \quad C_{px,min} = 0.2 * S_{DS} * I, \text{ ASCE 7 Eq. 12.10-2 (p. 75)}$$

Vertical Distribution Factor: $F_{px} = (\sum F_i / \sum W_i) * w_{px}$, ASCE 7 Eq. 12.10-1 (p. 75)

[illegible]

kpff Consulting Engineers 45 Fremont Street, 28th Floor San Francisco, California 94105 (415) 989-1004 FAX (415) 989-1552	project:			
	location:			
	client:			

SHEAR WALL DESIGN**Plywood Sheathing**

Level (ft)	F _x (kips)	Area, A _x (ft ²)
1	8	1184

EW DIRECTION

Zone	Level	Trib Area (ft ²)	F _{x, zone} (kips)	V _{x, zone} (kips)	L _{wall} (ft)	V _{wall, ASD} (plf)	Shear Wall Type	Wall Capacity	DCR (%)
A-1	1	592	3.87	3.87	22.5	172	A	310	55%
A-2	1	592	3.87	3.87	18	215	A	310	69%

NS DIRECTION

Zone	Level	Trib Area (ft ²)	F _{x, zone} (kips)	V _{x, zone} (kips)	L _{wall} (ft)	V _{wall, ASD} (plf)	Shear Wall Type	Wall Capacity	DCR (%)
1	1	592	3.87	3.87	10	387	B	460	84%
2	1	592	3.87	3.87	10	387	B	460	84%

 kpff Consulting Engineers 45 Fremont Street, 28th Floor San Francisco, California 94105 (415) 989-1004 FAX (415) 989-1552	project: Venetia Valley Restroom	by: rk	sheet no:
	location:	date:	
	client: SVA		job no:
			2200173

SHEAR WALL OVERTURNING CHECKS

[ASD]

Notes:

$$S_{DS} = 1.20$$

 ΣM_{OT} = Sum of overturning moments at story, ASD

Determined in other worksheets

 ΣM_R = Sum of resisting moments at story

 M_{NET} = net overturning moment using the LC: $E - (0.6 - 0.14 S_{DS}) * DL$
 T = resulting uplift: M_{NET} / L_{eff}
 $L_{w,eff}$ = Effective width of wall for resisting couple, taken as length of wall minus 2 ft
(1) L_{eff} updated manually to account for gravity posts

 T_{LRFD} = calculated using LC: $1.4E - (0.9 - 0.2 S_{DS}) * DL$, used for tiedown anchorage design

For a sample hand calculation of how the values in each row are calculated, see following pages.

EAST-WEST DIRECTION (X)

Shear Wall	H _{wall} (ft)	L _{wall} (ft)	V _{wall} (plf)	ΣV_{WALL} (kip)	ΣM_{OT} (k-ft)	Weight (plf)	Trib DL (plf)	ΣM_R (k-ft)	M _{NET} (k-ft)	L _{w,eff} (ft)	T (kip)	T _{LRFD} (kip)
WA_1	13.8	22.5	172	3.9	53	234	42	70	23	20.5	1.1	1.4
WA_2	13.8	10.0	215	2.2	30	234	42	14	24	8.0	3.0	4.0

NORTH-SOUTH DIRECTION (Y)

Shear Wall	H _{wall} (ft)	L _{wall} (ft)	V _{wall} (plf)	ΣV_{WALL} (kip)	ΣM_{OT} (k-ft)	Weight (plf)	Trib DL (plf)	ΣM_R (k-ft)	M _{NET} (k-ft)	L _{w,eff} (ft)	T (kip)	T _{LRFD} (kip)
W1_1	10.0	5.0	387	1.9	19	170	231	5	17	3.0	5.7	7.9
W1_2	10.0	5.0	387	1.9	19	170	231	5	17	3.0	5.7	7.9

 Consulting Engineers 45 Fremont Street, 28th Floor San Francisco, California 94105 (415) 989-1004 FAX (415) 989-1552	project:			
	location:			
	client:			

[ASD]

SHEAR WALL HOLDOWN & POST DESIGN

Typ Max DCR = 0.97
ATS DSA Reduction = 0.80

Notes:

$$S_{DS} = 1.20$$

$$T_E = \text{resulting uplift: } M_{NET}/L_{eff}$$

$$T = C_E \cdot \text{gravity load, using [LC10: } E-(0.6-0.14 S_{DS})D \text{]}$$

$$C_E = M_{OT}/L_{EFF}$$

$$C = C_E + \text{gravity load, max of [LC8: } (1+0.14 S_{DS})D+E \text{] \& [LC9: } (1+0.14 S_{DS})D+0.75(L+E) \text{]}$$

- (1) Seismic Load E is at ASD level
- (2) Max DCR manually changed to be higher than design DCR.
- (3) See following pages for Simpson Strong Tie Catalog

SST HOLDOWN CAPACITY ⁽³⁾

HDU Type	Model	Rod Dia. [in]	Capacity [lbs]	0.8*T _{all} [kip]	d _a [in]
HD-7	(2) HDU19	1 1/4	38720	30.976	0.180
HD-6	(2) HDU14	1	28890	23.112	0.172
HD-5	(2) HDU11	1	22350	17.880	0.137
HD-4	(2) HDU8	7/8	15740	12.592	0.113
HD-3	HDU14	1	14445	11.556	0.172
HD-2	HDU11	1	11175	8.940	0.137
HD-1	HDU8	7/8	7870	6.296	0.113
			38140	30512.000	

POST CAPACITY

	Post	Grade	Wall Thickness	L _e (ft)	C _{all} (lbs)	T _{all} (lbs)
< 27 ft	PSL 7 x 11 7/8 *	PSL 2.0E		25.8	30407	275583
	PSL 7 x 9 1/2 *	PSL 2.0E	8x	25.8	24326	220466
	PSL 7 x 7	PSL 1.8E		25.8	10391	140907
	PSL 5 1/4 x 11 7/8 *	PSL 2.0E		25.8	13913	206687
	PSL 5 1/4 x 9 1/2 *	PSL 2.0E	6x	25.8	11130	165350
< 19 ft	PSL 5 1/4 x 7 *	PSL 1.8E		25.8	7863	105680
	PSL 5 1/4 x 11 7/8 *	PSL 2.0E		17.8	25902	211030
	PSL 5 1/4 x 9 1/2 *	PSL 2.0E		17.8	20722	168824
	PSL 5 1/4 x 7 *	PSL 1.8E	6x	17.8	16305	107900
	6x12 *	No. 1		17.8	17233	68310
< 17.5 ft	6x10 *	No. 2		17.8	14236	56430
	6x8 *	No. 2		17.8	11281	44550
	PSL 5 1/4 x 11 7/8 *	PSL 2.0E		16.3	29261	212073
	6x12 *	No. 1	6x	16.3	20350	68310
	6x10 *	No. 2		16.3	16810	56430
< 17.5 ft	6x8 *	No. 2		16.3	13334	44550
	4x6		6x		7017	

EAST-WEST DIRECTION (X)

			GRAVITY LOADS		COMPRESSION				TENSION						NOTES
Shear Wall	Wall Thickness	Height	Add'l DL	Add'l LL	C _E [lbs]	C (lbs)	Post	DCR	T _E [kip]	T [kip]	d _{B,POST} [in]	INCLUDE DL?	HDU Type	DCR	
WA_1	6x	13.75			1197.3	1197.3	4x6	0.17	1.1	1.1	0.01	NO	HD-1	0.18	
WA_2	6x	13.75			295.6	295.6	4x6	0.04	3.0	3.0	0.02	NO	HD-1	0.47	

NORTH-SOUTH DIRECTION (Y)

			GRAVITY LOADS		COMPRESSION				TENSION						
Shear Wall	Wall Thickness	Height	Add'l DL	Add'l LL	C _E [kip]	C (kip)	Post	DCR	T _E [kip]	T [kip]	d _{a,POST} [in]	INCLUDE DL?	HDU Type	DCR	NOTES
W1_1	6x	10.5			96.8	96.8	4x6	0.01	5.7	5.7	0.02	NO	HD-1	0.91	

 kpff Consulting Engineers 45 Fremont Street, 28th Floor San Francisco, California 94105 (415) 989-1004 FAX (415) 989-1552	project:		
	location:		
	client:		

TIEDOWN ANCHORAGE DESIGN

ACI318-19 Ch. 17

Tiedown anchors are sized using the ductile anchor method of ACI 318-14, 17.2.34.3 9(a)

INPUT:

$f_c =$	3	ksi	[Concrete Strength]	<u>Anchor Steel Strength:</u>	<u>Pullout Strength:</u>	<u>Breakout Strength:</u>
$F_y =$	36	ksi	[Anchor yield strength]	$N_{sa} = A_e \cdot F_u$	$N_{pn} = \psi_{c,p} \cdot 8 \cdot A_{brg} \cdot f_c$	Based on anchor reinforcement capacity
$F_u =$	58	ksi	[Anchor ultimate strength]		$A_{brg} = l_{washer}^2 - \pi \phi_{AB}^2 / 4$	$N_n = A_s \cdot F_y$
$F_{y,bar} =$	60	ksi	[Rebar yield strength]			
$\Phi =$	0.75		[Breakout, Steel element]			
$\Phi =$	0.70		[Pullout & Pryout]			


ANCHORAGE CHECKS:

HDU Type	N_{ua} (kip)		ϕ_{AB} (in)	Plate Washer (in)	No. of Legs	Reinf. #	Steel strength		Pullout Strength		Breakout strength		Ductility Check		
	ASD	LRFD					N_{sa} (kip)	$N_{ua} / \Phi N_{sa}$	N_{pn} (kip)	$N_{ua} / \Phi N_{pn}$	N_n (kip)	$N_{ua} / \Phi N_n$	(a) $N_{ua} / 1.2 N_{sa}$	(b) N_{ua} / N_c	(a) > (b)?
HD-1	8	11	0.875	3	2	4	26.8	0.55	151.2	0.10	24.0	0.61	0.34	0.07	O.K.

PLATE WASHER CHECK:

Check plate washer for bending

$T_u =$	11	kip	$q_u = T_u / A_{brg} =$	1.3	ksi
$w =$	3	in	$M_u = w \cdot q_u \cdot L^2 / 2 =$	2.01	kip-in
$t =$	1	in	$\Phi =$	0.9	
$F_y =$	36	ksi	$\Phi M_n = \Phi F_y \cdot Z =$	24.3	kip-in
$\phi_{AB} =$	1	in			
$A_{brg} =$	8.21	in ²	DCR =	0.08	OK
$L = (w - \phi_{AB}) / 2 =$	1.00	in			
$Z = w \cdot t^2 / 4 =$	0.75	in ³			





D1 - FOUNDATION

Foundation Design**Design Criteria**Building Dimension: $L := 34.8 \text{ ft}$ $B := 22.5 \text{ ft}$ $H := 12.5 \text{ ft}$ Building Weight: $W := 60 \text{ kip}$ Grade Beam Dimension: $B_{gb} := 1.5 \text{ ft}$ $D_{gb} := 2 \text{ ft}$ Slab on Grade Thickness: $t_{slab} := 5 \text{ in}$ Concrete Property: $f'_c := 3000 \text{ psi}$ $\gamma_c := 150 \text{ pcf}$ **Seismic**Seismic Parameter: $S_{ds} := 1.2$ $\rho := 1.0$ $C_s := 0.185$ $\Omega_o := 3$ Base Shear: $V_E := 1 \cdot C_s \cdot W = 11.1 \text{ kip}$ Overturning Moment: $M_E := V_E \cdot H = 138.75 \text{ ft} \cdot \text{kip}$ Seismic governs the design for foundation.

Overturning Seismic governs the design for overturning.

Consider the entire building as one unit

Min. effect ASD load combination $(0.6 - 0.14Sds)D + 0.7E$

$$OTM := 0.7 \cdot M_E = 97.125 \text{ kip} \cdot \text{ft}$$

Total weight of the building including foundation:

$$P_{total} := W + \gamma_c \cdot ((2 \cdot L + 4 \cdot (B - B_{gb})) \cdot D_{gb} \cdot B_{gb} + (B + B_{gb}) \cdot (L + B_{gb}) \cdot t_{slab}) = 183.57 \text{ kip}$$

Resisting Moment:

$$M_o := (0.6 - 0.14 Sds) \cdot P_{total} \cdot \frac{(B + B_{gb})}{2} = 951.627 \text{ kip} \cdot \text{ft}$$

Factor of Safety against overturning moment:

$$FS := \frac{M_o}{OTM} = 9.798 \quad \text{OK}$$

Created with Mathcad Express. See www.mathcad.com for more information.

kpff Consulting Engineers 45 Fremont Street, 28th Floor Foundations design conform to California (415) 989-1004 Fax (415) 989-1552	Project: Venetia Valley	By: RK	Page D - 3
		date: 5/15/2023	
	Client: SVA	Job No.: 2200173	Rev. No. 121.01

Gr = 1500 psf DL + LL CBC2022 - TABLE 1806.2

Lat = 100 pcf

Lat = 130 pcf Basic Load Combinations


Footing Information

Weight 60 kips

Location Foundation/Second Floor

Earthquake Loads

S_{DS} =	1.20	g	Seismic Design Spectral Acceleration
P_E =	7	kips	Vertical seismic force resultant
$P_{E,Dist.}$ =	12	ft	Horizontal distance from point "a" to P_E
$M_{E,PE}$ =	86	k-ft	(taken at Point a)
M_{Eh} =	53	k-ft	(taken at Point a)
$M_{E,Total}$ =	140	k-ft	(taken at Point a)



Foundation Dimensions

Component	Depth (ft)	Width (ft)	Length (ft)	Notes
Footing	2.00	1.50	24.00	
Surcharge	1.00			

Gravity Loads: Forces and Moments (D + L)

Load	Dead (k)	Live (k)	Dist. (ft)	Dead (k-ft)	Live (k-ft)	Notes
Footing	11		12.00	130		
Surcharge	4		12.00	52		
Roof LL		1	12.00		6	
P_1	5	4	13.25	66	52	
P_2						
P_3						
P_4						
P_5						
P_6						
P_7						
P_8						
P_9						
P_{10}						
Sum	20	4	----	248	52	Sum excludes L_r

Allowable Soil Bearing Pressures

Soil density ρ = 120 pcf CBC2022 - TABLE 1806.2
Add displaced soil? No

Loads	$q_{allow,net}$	$q_{allow,gross}$	W/O added displaced soil (depth accounted in $q_{allow,net}$)
D + L	1500 psf	1500 psf	$q_{allow,gross} = q_{allow,net}$
D + L + E	1500 psf	1500 psf	With additional displaced soil increase $q_{allow,gross} = q_{allow,net} + (\text{displaced soil wt/ftg area})$ Values for q_{allow} obtained from soils report

kpff Consulting Engineers 45 Fremont Street, 28th Floor Foundations design conform to California (415) 989-1004 Fax (415) 989-1552	Project: Venetia Valley		By: RK	Page D - 4
	Client: SVA		date: 5/15/2023	
			Job No.: 2200173	
			Rev. No. 121.01	

Required Footing Width

$W_{reqd} =$ (if inside kern, $e \leq L_{ftg} / 6$)

(if outside kern, $e > L_{ftg} / 6$)

$$W_{reqd} = \frac{R}{q_{allow} L_{ftg}} \left(1 + \frac{6e}{L_{ftg}} \right) \quad (\text{Eq. 1})$$

$$W_{reqd} = \frac{2R}{3q_{allow}(L-x)}, \text{ or } \frac{2R}{3q_{allow}x} \quad (\text{Eq. 2})$$

($x > L/2$) ($x \leq L/2$)


ASD Load Combinations for Soil Bearing

Load Combination 1: D (CBC 2022 Eq. 16-8)

Check: OK

$M_a =$	248	kip-ft	Sum of the moments about left end
$R =$	20	kips	Factored load reaction
$x =$	12.31	ft	Resultant location from left end, $x = M_a / R$
$e =$	0.31	ft	Eccentricity, $e = x - (L_{ftg} / 2)$
$e_{kern} =$	4.00	ft	Kern distance, $e_{kern} = L_{ftg} / 6$
Inside kern?	Yes		Resultant is inside kern if $e \leq e_{kern}$
$W_{reqd} =$	0.60	ft	Required width (see Eq. 1 and Eq. 2 above)
Sufficient width?	OK		

For $W_{ftg} =$ 1.50 ft., $q_{max} =$ 602 at dist. = 24.00 ft
 $q_{min} =$ 515 at dist. = 0.00 ft




Load Combination 2: D + L (CBC 2022 Eq. 16-9)

Check: OK

$M_a =$	299	kip-ft	Sum of the moments about left end
$R =$	24	kips	Factored load reaction
$x =$	12.46	ft	Resultant location from left end, $x = M_a / R$
$e =$	0.46	ft	Eccentricity, $e = x - (L_{ftg} / 2)$
$e_{kern} =$	4.00	ft	Kern distance, $e_{kern} = L_{ftg} / 6$
Inside kern?	Yes		Resultant is inside kern if $e \leq e_{kern}$
$W_{reqd} =$	0.74	ft	Required width (see Eq. 1 and Eq. 2 above)
Sufficient width?	OK		

For $W_{ftg} =$ 1.50 ft., $q_{max} =$ 744 at dist. = 24.00 ft
 $q_{min} =$ 590 at dist. = 0.00 ft




kpff Consulting Engineers 45 Fremont Street, 28th Floor Foundations design conform to California (415) 989-1004 Fax (415) 989-1552	Project: Venetia Valley		By: RK	Page D - 5
	Client: SVA		date: 5/15/2023	
			Job No.: 2200173	
			Rev. No. 121.01	

Load Combination 3: D + Lr (CBC 2022 Eq. 16-10)

Check: OK

$M_a =$	254	kip-ft	Sum of the moments about left end
$R =$	21	kip	Factored load reaction
$x =$	12.30	ft	Resultant location from left end, $x = M_a / R$
$e =$	0.30	ft	Eccentricity, $e = x - (L_{ftg} / 2)$
$e_{kern} =$	4.00	ft	Kern distance, $e_{kern} = L_{ftg} / 6$
Inside kern?	Yes		Resultant is inside kern if $e \leq e_{kern}$
$W_{reqd} =$	0.62	ft	Required width (see Eq. 1 and Eq. 2 above)
Sufficient width?	OK		

For $W_{ftg} = 1.50$ ft., $q_{max} = 616$ at dist. = 24.00 ft
 $q_{min} = 529$ at dist. = 0.00 ft




Load Combination 4: D + 0.75(L) + 0.75(Lr) (CBC 2022 Eq. 16-11)

Check: OK

$M_a =$	291	kip-ft	Sum of the moments about left end
$R =$	23	kips	Factored load reaction
$x =$	12.42	kips	Resultant location from left end, $x = M_a / R$
$e =$	0.42	ft	Eccentricity, $e = x - (L_{ftg} / 2)$
$e_{kern} =$	4.00	ft	Kern distance, $e_{kern} = L_{ftg} / 6$
Inside kern?	Yes		Resultant is inside kern if $e \leq e_{kern}$
$W_{reqd} =$	0.72	ft	Required width (see Eq. 1 and Eq. 2 above)
Sufficient width?	OK		

For $W_{ftg} = 1.50$ ft., $q_{max} = 719$ at dist. = 24.00 ft
 $q_{min} = 582$ at dist. = 0.00 ft



Load Combination 8a: (1 + 0.14 SDS) D + 0.7(Eh) (CBC 2022 Eq. 16-12)

Check: OK


$M_a =$	387	kip-ft	Sum of the moments about left end
$R =$	29	kips	Factored load reaction
$x =$	13.56	ft	Resultant location from left end, $x = M_a / R$
$e =$	1.56	ft	Eccentricity, $e = x - (L_{ftg} / 2)$

kpff Consulting Engineers 45 Fremont Street, 28th Floor Foundations design conform to California (415) 989-1004 Fax (415) 989-1552	Project: Venetia Valley		By: RK	Page D - 6
	Client: SVA		date: 5/15/2023	
			Job No.: 2200173	
			Rev. No. 121.01	

$e_{\text{kern}} = 4.00$ ft Kern distance, $e_{\text{kern}} = L_{\text{ftg}} / 6$
Inside kern? Yes Resultant is inside kern if $e \leq e_{\text{kern}}$

$W_{\text{reqd}} = 1.10$ ft Required width (see Eq. 1 and Eq. 2 above)
Sufficient width? OK

For $W_{\text{ftg}} = 1.50$ ft., $q_{\text{max}} = 1102$ at dist. = 24.00 ft
 $q_{\text{min}} = 483$ at dist. = 0.00 ft




Load Combination 8b: (1 - 0.14 SDS) D - 0.7(Eh) (CBC 2022 Eq. 16-12) Check: OK

$M_a = 108$ kip-ft Sum of the moments about left end
 $R = 12$ kips Factored load reaction
 $x = 9.26$ ft Resultant location from left end, $x = M_a / R$
 $e = -2.74$ ft Eccentricity, $e = x - (L_{\text{ftg}} / 2)$
 $e_{\text{kern}} = 4.00$ ft Kern distance, $e_{\text{kern}} = L_{\text{ftg}} / 6$
Inside kern? Yes Resultant is inside kern if $e \leq e_{\text{kern}}$

$W_{\text{reqd}} = 0.55$ ft Required width (see Eq. 1 and Eq. 2 above)
Sufficient width? OK

For $W_{\text{ftg}} = 1.50$ ft., $q_{\text{max}} = 548$ at dist. = 0.00 ft
 $q_{\text{min}} = 102$ at dist. = 24.00 ft




Load Combination 9a: (1 + 0.105 SDS) D + 0.525(Eh) + 0.75(L) (CBC 2022 Eq. 16-14) Check: OK

$M_a = 391$ kip-ft Sum of the moments about left end
 $R = 29$ kips Factored load reaction
 $x = 13.32$ ft Resultant location from left end, $x = M_a / R$
 $e = 1.32$ ft Eccentricity, $e = x - (L_{\text{ftg}} / 2)$
 $e_{\text{kern}} = 4.00$ ft Kern distance, $e_{\text{kern}} = L_{\text{ftg}} / 6$
Inside kern? Yes Resultant is inside kern if $e \leq e_{\text{kern}}$

$W_{\text{reqd}} = 1.08$ ft Required width (see Eq. 1 and Eq. 2 above)
Sufficient width? OK

For $W_{\text{ftg}} = 1.50$ ft., $q_{\text{max}} = 1084$ at dist. = 24.00 ft
 $q_{\text{min}} = 547$ at dist. = 0.00 ft

kpff Consulting Engineers 45 Fremont Street, 28th Floor Foundations design conform to California (415) 989-1004 Fax (415) 989-1552	Project: Venetia Valley		By: RK	Page D - 7
	Client: SVA		date: 5/15/2023	
			Job No.: 2200173	
			Rev. No. 121.01	




Load Combination 9b: (1 - 0.105 SDS) D - 0.525(Eh) + 0.75(L) (CBC 2022 Eq. 16-14)

Check: OK

M_a =	182	kip-ft	Sum of the moments about left end
R =	17	kips	Factored load reaction
x =	10.88	ft	Resultant location from left end, $x = M_a / R$
e =	-1.12	ft	Eccentricity, $e = x - (L_{ftg} / 2)$
e_{kern} =	4.00	ft	Kern distance, $e_{kern} = L_{ftg} / 6$
Inside kern?	Yes		Resultant is inside kern if $e \leq e_{kern}$
W_{reqd} =	0.60	ft	Required width (see Eq. 1 and Eq. 2 above)
Sufficient width?	OK		

For $W_{ftg} = 1.50$ ft., $q_{max} = 595$ at dist. = 0.00 ft
 $q_{min} = 334$ at dist. = 24.00 ft




Load Combination 10a: (0.6)(D) + 0.7(Eh) (CBC 2022 Eq. 16-16)

Check: OK

M_a =	253	kip-ft	Sum of the moments about left end
R =	17	kips	Factored load reaction
x =	14.80	ft	Resultant location from left end, $x = M_a / R$
e =	2.80	ft	Eccentricity, $e = x - (L_{ftg} / 2)$
e_{kern} =	4.00	ft	Kern distance, $e_{kern} = L_{ftg} / 6$
Inside kern?	Yes		Resultant is inside kern if $e \leq e_{kern}$
W_{reqd} =	0.81	ft	Required width (see Eq. 1 and Eq. 2 above)
Sufficient width?	OK		

For $W_{ftg} = 1.50$ ft., $q_{max} = 809$ at dist. = 24.00 ft
 $q_{min} = 142$ at dist. = 0.00 ft



Load Combination 10b: (0.6)(D) - 0.7(Eh) (CBC 2022 Eq. 16-16)

Check: OK

M_a =	44	kip-ft	Sum of the moments about left end
R =	7	kips	Factored load reaction
x =	6.24	ft	Resultant location from left end, $x = M_a / R$
e =	-5.76	ft	Eccentricity, $e = x - (L_{ftg} / 2)$
e_{kern} =	4.00	ft	Kern distance, $e_{kern} = L_{ftg} / 6$
Inside kern?	No		Resultant is inside kern if $e \leq e_{kern}$


kpff Consulting Engineers 45 Fremont Street, 28th Floor Foundations design conform to California (415) 989-1004 Fax (415) 989-1552	Project: Venetia Valley		By: RK	Page D - 8
			date: 5/15/2023	
	Client: SVA		Job No.: 2200173	
			Rev. No. 121.01	

$W_{reqd} = 0.50$ ft

Required width (see Eq. 1 and Eq. 2 above)

Sufficient width?

OK



Grade Beam - Short Side:

Consider the grade beam in the long direction resisting half of the seismic moment.

Grade Beam Length in Long Direction: $L_{gb} := B + B_{gb} = 24 \text{ ft}$

From previous calculation, the highest uniform bearing load is 837 psf from load combination: $(1 + 0.14 \text{ SDS}) D + 0.7(E_h)$

Using conversion factor of 1.4 to convert the max soil pressure into LRFD

Max. Soil Pressure: $q_u := 1.4 \cdot 837 \text{ psf} = 1171.8 \text{ psf}$

Uniform Linear Loads Along Grade Beam: $w_u := q_u \cdot B_{gb} = 1.758 \text{ klf}$

Max. Moment per AISC Table 3-22c: $M_u := 0.1 \cdot w_u \cdot L_{gb}^2 = 101.244 \text{ ft} \cdot \text{kip}$

Max. Shear per AISC Table 3-22c: $V_u := 1.1 \cdot w_u \cdot L_{gb} = 46.403 \text{ kip}$

Flexural

Use (3) #8bars at bottom & #4 Ties

$$d_b := 1 \text{ in} \quad A_{bar} := 0.79 \text{ in}^2 \quad n := 3 \quad \lambda := 1.0 \quad d_{bv} := 0.5 \text{ in}$$

$$d := D_{gb} - 3 \text{ in} - 0.5 \cdot d_b = 20.5 \text{ in} \quad f_y := 60 \text{ ksi}$$

$$A_{smin} := \max \left(\frac{3 \cdot \sqrt{3000 \text{ psi}} \cdot B_{gb} \cdot d}{f_y}, 200 \text{ psi} \cdot B_{gb} \cdot \frac{d}{f_y} \right) = 1.23 \text{ in}^2$$

$$A_s := n \cdot A_{bar} = 2.37 \text{ in}^2 > A_{smin} = 1.23 \text{ in}^2 \quad \text{OK}$$

$$a := \frac{A_s \cdot f_y}{0.85 B_{gb} \cdot f'_c} = 3.098 \text{ in}$$

$$\phi M_n := 0.9 \cdot A_s \cdot f_y \cdot \left(d - \frac{a}{2} \right) = 202.112 \text{ kip} \cdot \text{ft} > M_u = 101.244 \text{ kip} \cdot \text{ft} \quad \text{OK}$$

Shear

Provide shear reinforcing: #4 @ 12" o.c.

$$\phi V_c := 2 \cdot 0.75 \cdot d \cdot 1 \text{ ft} \cdot \lambda \cdot \sqrt{3000 \text{ psi}} = 20.211 \text{ kip}$$

$$s := 12 \text{ in} \quad A_v := 0.2 \text{ in}^2$$

$$\phi V_s := \frac{2 \cdot A_v \cdot f_y \cdot d}{s} = 41 \text{ kip}$$

$$\phi V := \phi V_s + \phi V_c = 61.211 \text{ kip} > V_u = 46.403 \text{ kip}$$

OK

kpff Consulting Engineers 45 Fremont Street, 28th Floor Foundations design conform to California (415) 989-1004 Fax (415) 989-1552	Project: Venetia Valley	By: RK	Page D - 10
		date: 5/15/2023	
	Client: SVA	Job No.: 2200173	Rev. No. 121.01

Gr = 1500 psf DL + LL CBC2022 - TABLE 1806.2

Lat = 100 pcf

Lat = 130 pcf Basic Load Combinations


Footing Information

Weight 60 kips

Location Foundation/Second Floor

Earthquake Loads

S_{DS} =	1.20	g	Seismic Design Spectral Acceleration
P_E =	7	kips	Vertical seismic force resultant
$P_{E,Dist.}$ =	18	ft	Horizontal distance from point "a" to P_E
$M_{E,PE}$ =	131	k-ft	(taken at Point a)
M_{Eh} =	38	k-ft	(taken at Point a)
$M_{E,Total}$ =	169	k-ft	(taken at Point a)



Foundation Dimensions

Component	Depth (ft)	Width (ft)	Length (ft)	Notes
Footing	2.00	1.50	36.50	
Surcharge	1.00			

Gravity Loads: Forces and Moments (D + L)

Load	Dead (k)	Live (k)	Dist. (ft)	Dead (k-ft)	Live (k-ft)	Notes
Footing	16		18.25	300		
Surcharge	7		18.25	120		
Roof LL		1	18.25		9	
P_1						
P_2						
P_3						
P_4						
P_5						
P_6						
P_7						
P_8						
P_9						
P_{10}						
Sum	23	0	----	420	0	Sum excludes L_r

Allowable Soil Bearing Pressures

Soil density ρ = 120 pcf CBC2022 - TABLE 1806.2
Add displaced soil? No

Loads	$q_{allow,net}$	$q_{allow,gross}$	W/O added displaced soil (depth accounted in $q_{allow,net}$)
D + L	1500 psf	1500 psf	$q_{allow,gross} = q_{allow,net}$
D + L + E	1500 psf	1500 psf	With additional displaced soil increase $q_{allow,gross} = q_{allow,net} + (\text{displaced soil wt/ftg area})$ Values for q_{allow} obtained from soils report

kpff Consulting Engineers 45 Fremont Street, 28th Floor Foundations design conform to California (415) 989-1004 Fax (415) 989-1552	Project: Venetia Valley		By: RK	Page D - 11
			date: 5/15/2023	
	Client: SVA		Job No.: 2200173	
			Rev. No. 121.01	

Required Footing Width

$W_{reqd} =$ (if inside kern, $e \leq L_{ftg} / 6$)

$$W_{reqd} = \frac{R}{q_{allow} L_{ftg}} \left(1 + \frac{6e}{L_{ftg}} \right) \quad (\text{Eq. 1})$$

(if outside kern, $e > L_{ftg} / 6$)

$$W_{reqd} = \frac{2R}{3q_{allow}(L-x)}, \text{ or } \frac{2R}{3q_{allow}x} \quad (\text{Eq. 2})$$

(x > L/2) (x ≤ L/2)


ASD Load Combinations for Soil Bearing

Load Combination 1: D (CBC 2022 Eq. 16-8)

Check: OK

$M_a =$	420	kip-ft	Sum of the moments about left end
$R =$	23	kips	Factored load reaction
$x =$	18.25	ft	Resultant location from left end, $x = M_a / R$
$e =$	0.00	ft	Eccentricity, $e = x - (L_{ftg} / 2)$
$e_{kern} =$	6.08	ft	Kern distance, $e_{kern} = L_{ftg} / 6$
Inside kern?	Yes		Resultant is inside kern if $e \leq e_{kern}$
$W_{reqd} =$	0.42	ft	Required width (see Eq. 1 and Eq. 2 above)
Sufficient width?	OK		

For $W_{ftg} =$ 1.50 ft., $q_{max} =$ 420 at dist. = 36.50 ft
 $q_{min} =$ 420 at dist. = 0.00 ft




Load Combination 2: D + L (CBC 2022 Eq. 16-9)

Check: OK

$M_a =$	420	kip-ft	Sum of the moments about left end
$R =$	23	kips	Factored load reaction
$x =$	18.25	ft	Resultant location from left end, $x = M_a / R$
$e =$	0.00	ft	Eccentricity, $e = x - (L_{ftg} / 2)$
$e_{kern} =$	6.08	ft	Kern distance, $e_{kern} = L_{ftg} / 6$
Inside kern?	Yes		Resultant is inside kern if $e \leq e_{kern}$
$W_{reqd} =$	0.42	ft	Required width (see Eq. 1 and Eq. 2 above)
Sufficient width?	OK		

For $W_{ftg} =$ 1.50 ft., $q_{max} =$ 420 at dist. = 36.50 ft
 $q_{min} =$ 420 at dist. = 0.00 ft




kpff Consulting Engineers 45 Fremont Street, 28th Floor Foundations design conform to California (415) 989-1004 Fax (415) 989-1552	Project: Venetia Valley		By: RK	Page D - 12
	Client: SVA		date: 5/15/2023	
			Job No.: 2200173	
			Rev. No. 121.01	

Load Combination 3: D + Lr (CBC 2022 Eq. 16-10)

Check: OK

$M_a =$	429	kip-ft	Sum of the moments about left end
$R =$	23	kip	Factored load reaction
$x =$	18.25	ft	Resultant location from left end, $x = M_a / R$
$e =$	0.00	ft	Eccentricity, $e = x - (L_{ftg} / 2)$
$e_{kern} =$	6.08	ft	Kern distance, $e_{kern} = L_{ftg} / 6$
Inside kern?	Yes		Resultant is inside kern if $e \leq e_{kern}$
$W_{reqd} =$	0.43	ft	Required width (see Eq. 1 and Eq. 2 above)
Sufficient width?	OK		

For $W_{ftg} = 1.50$ ft., $q_{max} = 429$ at dist. = 36.50 ft
 $q_{min} = 429$ at dist. = 0.00 ft




Load Combination 4: D + 0.75(L) + 0.75(Lr) (CBC 2022 Eq. 16-11)

Check: OK

$M_a =$	427	kip-ft	Sum of the moments about left end
$R =$	23	kips	Factored load reaction
$x =$	18.25	kips	Resultant location from left end, $x = M_a / R$
$e =$	0.00	ft	Eccentricity, $e = x - (L_{ftg} / 2)$
$e_{kern} =$	6.08	ft	Kern distance, $e_{kern} = L_{ftg} / 6$
Inside kern?	Yes		Resultant is inside kern if $e \leq e_{kern}$
$W_{reqd} =$	0.43	ft	Required width (see Eq. 1 and Eq. 2 above)
Sufficient width?	OK		

For $W_{ftg} = 1.50$ ft., $q_{max} = 427$ at dist. = 36.50 ft
 $q_{min} = 427$ at dist. = 0.00 ft



Load Combination 8a: (1 + 0.14 SDS) D + 0.7(Eh) (CBC 2022 Eq. 16-12)

Check: OK

$M_a =$	609	kip-ft	Sum of the moments about left end
$R =$	32	kips	Factored load reaction
$x =$	19.08	ft	Resultant location from left end, $x = M_a / R$
$e =$	0.83	ft	Eccentricity, $e = x - (L_{ftg} / 2)$

kpff Consulting Engineers 45 Fremont Street, 28th Floor Foundations design conform to California (415) 989-1004 Fax (415) 989-1552	Project: Venetia Valley		By: RK	Page D - 13
			date: 5/15/2023	
	Client: SVA		Job No.: 2200173	
			Rev. No. 121.01	


$e_{\text{kern}} = 6.08$ ft
Inside kern? Yes

Kern distance, $e_{\text{kern}} = L_{\text{ftg}} / 6$
Resultant is inside kern if $e \leq e_{\text{kern}}$

$W_{\text{reqd}} = 0.66$ ft
Sufficient width? OK

Required width (see Eq. 1 and Eq. 2 above)

For $W_{\text{ftg}} = 1.50$ ft., $q_{\text{max}} = 662$ at dist. = 36.50 ft
 $q_{\text{min}} = 503$ at dist. = 0.00 ft



Load Combination 8b: (1 - 0.14 SDS) D - 0.7(Eh) (CBC 2022 Eq. 16-12)

Check: OK


$M_a = 231$ kip-ft
 $R = 14$ kips
 $x = 16.36$ ft
 $e = -1.89$ ft
 $e_{\text{kern}} = 6.08$ ft
Inside kern? Yes

Sum of the moments about left end
Factored load reaction
Resultant location from left end, $x = M_a / R$
Eccentricity, $e = x - (L_{\text{ftg}} / 2)$
Kern distance, $e_{\text{kern}} = L_{\text{ftg}} / 6$
Resultant is inside kern if $e \leq e_{\text{kern}}$

$W_{\text{reqd}} = 0.34$ ft
Sufficient width? OK

Required width (see Eq. 1 and Eq. 2 above)

For $W_{\text{ftg}} = 1.50$ ft., $q_{\text{max}} = 337$ at dist. = 0.00 ft
 $q_{\text{min}} = 178$ at dist. = 36.50 ft



Load Combination 9a: (1 + 0.105 SDS) D + 0.525(Eh) + 0.75(L) (CBC 2022 Eq. 16-14)

Check: OK

$M_a = 561$ kip-ft
 $R = 30$ kips
 $x = 18.92$ ft
 $e = 0.67$ ft
 $e_{\text{kern}} = 6.08$ ft
Inside kern? Yes


Sum of the moments about left end
Factored load reaction
Resultant location from left end, $x = M_a / R$
Eccentricity, $e = x - (L_{\text{ftg}} / 2)$
Kern distance, $e_{\text{kern}} = L_{\text{ftg}} / 6$
Resultant is inside kern if $e \leq e_{\text{kern}}$

$W_{\text{reqd}} = 0.60$ ft
Sufficient width? OK

Required width (see Eq. 1 and Eq. 2 above)

For $W_{\text{ftg}} = 1.50$ ft., $q_{\text{max}} = 602$ at dist. = 36.50 ft
 $q_{\text{min}} = 482$ at dist. = 0.00 ft

kpff Consulting Engineers 45 Fremont Street, 28th Floor Foundations design conform to California (415) 989-1004 Fax (415) 989-1552	Project: Venetia Valley		By: RK	Page D - 14
	Client: SVA		date: 5/15/2023	
			Job No.: 2200173	
			Rev. No. 121.01	




Load Combination 9b: (1 - 0.105 SDS) D - 0.525(Eh) + 0.75(L) (CBC 2022 Eq. 16-14)

Check: OK

$M_a =$	278	kip-ft	Sum of the moments about left end
$R =$	16	kips	Factored load reaction
$x =$	17.03	ft	Resultant location from left end, $x = M_a / R$
$e =$	-1.22	ft	Eccentricity, $e = x - (L_{ftg} / 2)$
$e_{kern} =$	6.08	ft	Kern distance, $e_{kern} = L_{ftg} / 6$
Inside kern?	Yes		Resultant is inside kern if $e \leq e_{kern}$
$W_{reqd} =$	0.36	ft	Required width (see Eq. 1 and Eq. 2 above)
Sufficient width?	OK		

For $W_{ftg} =$	1.50	ft.,	$q_{max} =$	358	at dist. =	0.00	ft
			$q_{min} =$	238	at dist. =	36.50	ft




Load Combination 10a: (0.6)(D) + 0.7(Eh) (CBC 2022 Eq. 16-16)

Check: OK

$M_a =$	379	kip-ft	Sum of the moments about left end
$R =$	19	kips	Factored load reaction
$x =$	20.11	ft	Resultant location from left end, $x = M_a / R$
$e =$	1.86	ft	Eccentricity, $e = x - (L_{ftg} / 2)$
$e_{kern} =$	6.08	ft	Kern distance, $e_{kern} = L_{ftg} / 6$
Inside kern?	Yes		Resultant is inside kern if $e \leq e_{kern}$
$W_{reqd} =$	0.45	ft	Required width (see Eq. 1 and Eq. 2 above)
Sufficient width?	OK		

For $W_{ftg} =$	1.50	ft.,	$q_{max} =$	449	at dist. =	36.50	ft
			$q_{min} =$	239	at dist. =	0.00	ft



Load Combination 10b: (0.6)(D) - 0.7(Eh) (CBC 2022 Eq. 16-16)

Check: OK

$M_a =$	125	kip-ft	Sum of the moments about left end
$R =$	9	kips	Factored load reaction
$x =$	14.25	ft	Resultant location from left end, $x = M_a / R$
$e =$	-4.00	ft	Eccentricity, $e = x - (L_{ftg} / 2)$
$e_{kern} =$	6.08	ft	Kern distance, $e_{kern} = L_{ftg} / 6$
Inside kern?	Yes		Resultant is inside kern if $e \leq e_{kern}$


kpff Consulting Engineers 45 Fremont Street, 28th Floor Foundations design conform to California (415) 989-1004 Fax (415) 989-1552	Project: Venetia Valley		By: RK	Page D - 15
			date: 5/15/2023	
	Client: SVA		Job No.: 2200173	
			Rev. No. 121.01	

W_{reqd} = 0.27 ft

Required width (see Eq. 1 and Eq. 2 above)

Sufficient width?

OK



Grade Beam - Long Side:

Consider the grade beam in the long direction resisting half of the seismic moment.

Grade Beam Length in Long Direction: $L_{gb} := L + B_{gb} = 36.3 \text{ ft}$

From previous calculation, the highest uniform bearing load is 613 psf from load combination: $(1 + 0.14 \text{ SDS}) D + 0.7(E_h)$

Using conversion factor of 1.4 to convert the max soil pressure into LRFD

Max. Soil Pressure: $q_u := 1.4 \cdot 613 \text{ psf} = 858.2 \text{ psf}$

Uniform Linear Loads Along Grade Beam: $w_u := q_u \cdot B_{gb} = 1.287 \text{ klf}$

Max. Moment per AISC Table 3-22c: $M_u := 0.1 \cdot w_u \cdot L_{gb}^2 = 169.626 \text{ ft} \cdot \text{kip}$

Max. Shear per AISC Table 3-22c: $V_u := 1.1 \cdot w_u \cdot L_{gb} = 51.402 \text{ kip}$

Flexural

Use (3) #8bars at bottom & #4 Ties

$$d_b := 1 \text{ in} \quad A_{bar} := 0.79 \text{ in}^2 \quad n := 3 \quad \lambda := 1.0 \quad d_{bv} := 0.5 \text{ in}$$

$$d := D_{gb} - 3 \text{ in} - 0.5 \cdot d_b = 20.5 \text{ in} \quad f_y := 60 \text{ ksi}$$

$$A_{smin} := \max \left(\frac{3 \cdot \sqrt{3000} \text{ psi} \cdot B_{gb} \cdot d}{f_y}, 200 \text{ psi} \cdot B_{gb} \cdot \frac{d}{f_y} \right) = 1.23 \text{ in}^2$$

$$A_s := n \cdot A_{bar} = 2.37 \text{ in}^2 > A_{smin} = 1.23 \text{ in}^2 \quad \text{OK}$$

$$a := \frac{A_s \cdot f_y}{0.85 B_{gb} \cdot f'_c} = 3.098 \text{ in}$$

$$\phi M_n := 0.9 \cdot A_s \cdot f_y \cdot \left(d - \frac{a}{2} \right) = 202.112 \text{ kip} \cdot \text{ft} > M_u = 169.626 \text{ kip} \cdot \text{ft} \quad \text{OK}$$

Shear

Provide shear reinforcing: #4 @ 12" o.c.

$$\phi V_c := 2 \cdot 0.75 \cdot d \cdot 1 \text{ ft} \cdot \lambda \cdot \sqrt{3000} \text{ psi} = 20.211 \text{ kip}$$

$$s := 12 \text{ in} \quad A_v := 0.2 \text{ in}^2$$

$$\phi V_s := \frac{2 \cdot A_v \cdot f_y \cdot d}{s} = 41 \text{ kip}$$

$$\phi V := \phi V_s + \phi V_c = 61.211 \text{ kip} > V_u = 51.402 \text{ kip}$$

OK



E1 MISCELLANEOUS



Consulting Engineers
45 Fremont Street, 28th Floor
San Francisco, California 94105
(415) 989-1004 FAX (415) 989-1552

project:
location:
client:

EQUIPMENT ANCHORAGE-WALL MOUNTED

EQUIPMENT ANCHORAGE-WALL MOUNTED

REFERENCE: 2022 CBC, ASCE 7-16 Chapter 13

Equipment ID = Water Heater

Equipment Description = Water Heater - Wall Mounted

Base Material = Wall Mounted

W_p = weight of equipment = 230 lb

l = overall length = 25 in

w = overall width = 18 in

d = overall depth = 18 in

Center of Mass Location

CG_x = dist. in x-dir from Origin = 9 in

CG_y = dist. in y-dir from Origin = 9 in

CG_z = dist. in z-dir from Origin = 16.6666667 in

n = # of anchors = 4

m = # of fastener @ each anchor = 1

Seismic Accelerations

a_p = amplification factor = 1

R_p = response factor = 2.5

S_{DS} = spectral acceleration = 1.2

$\Omega_0 F_h$ = ASCE 7-10: 13.3-1, 13.3-2, 13.3-3 = 264.96 lb

$\Omega_0 F_v$ = vertical force = $0.2 S_{DS} W_p$ = 110.4 lb

Bolt Group Properties

x_{bar} = y-dist. of C.R. from Origin = 0 in

y_{bar} = y-dist. of C.R. from Origin = 9 in

z_{bar} = z-dist. of C.R. from Origin = 12 in

e_x = x-eccen. of C.G. from C.R. = 9 in




e_y = y-eccen. of C.G. from C.R. = 0 in

e_z = z-eccen. of C.G. from C.R. = 4.66666667 in

$I_y = \sum(d_y^2) = 324.0 \text{ in}^2$

$I_z = \sum(d_z^2) = 144.0 \text{ in}^2$

$I_{polar} = I_y + I_z = 468.0 \text{ in}^2$



I_p = Imp. Factor = 1

z = 1 ft

Ω_0 = Over. Factor = 2

h = 1 ft

Apply Ω_0 = Yes

= 1.16 W_p LRFD DESIGN

= 0.48 W_p LRFD DESIGN

ANCHOR LOCATIONS (UP TO 20 ANCHORS)

Bolt #	Y (W)	Z (L)	d_y	d_z	d_y^2	d_z^2	d^2
1	0.00	6.00	-9.0	-6.0	81.0	36.0	117.0
2	0.00	18.00	-9.0	6.0	81.0	36.0	117.0
3	18.00	6.00	9.0	-6.0	81.0	36.0	117.0
4	18.00	18.00	9.0	6.0	81.0	36.0	117.0
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							

SUM = $\sum d^2$ 468



Consulting Engineers

45 Fremont Street, 28th Floor

San Francisco, California 94105

(415) 989-1004 FAX (415) 989-1552

project:

location:

client:

EQUIPMENT ANCHORAGE-WALL MOUNTED

EQUIPMENT ANCHORAGE-WALL MOUNTED

REFERENCE: 2022 CBC, ASCE 7-16 Chapter 13

FASTENER FORCES: LOAD CASE 1: SEISMIC LOADING IN X-X DIRECTION + Z-Z DIRECTION

LRFD LOAD CASE:	1.2	DL+	1.0	EL
ASD LOAD CASE:	1.0	DL+	0.7	EL

	LRFD	ASD	
$M_x = (F_v * EL_{factor} + W_p * DL_{factor}) * -e_y =$	0	0	lb*in
$M_y = (F_v * EL_{factor} + W_p * DL_{factor}) * e_x + (F_h * EL_{factor}) * -e_z =$	2241.1	1900	lb*in
$M_z = (F_h * EL_{factor}) * e_y =$	0	0	lb*in

$$T_{fastener} = F_{ph} * EL_{factor} / (m * n) + M_y * d_z / I_z - M_z * d_y / I_y \quad (\text{negative tension indicates compression})$$

$$V_{y \text{ fastener}} = -M_x * d_z / I_p$$

$$V_{z \text{ fastener}} = M_x * d_y / I_p - (W_p * DL_{factor} + F_{pv} * EL_{factor}) / (m * n)$$

$$V_r = (V_y^2 + V_z^2)^{0.5}$$

			LRFD LEVEL				ASD LEVEL			
Bolt #	d _y (in)	d _z (in)	T (lbs)	V _y (lbs)	V _z (lbs)	V _r (lbs)	T (lbs)	V _y (lbs)	V _z (lbs)	V _r (lbs)
1	-9	-6	-27.14	0.00	-96.60	96.60	-32.80	0.00	-76.82	76.82
2	-9	6	159.62	0.00	-96.60	96.60	125.53	0.00	-76.82	76.82
3	9	-6	-27.14	0.00	-96.60	96.60	-32.80	0.00	-76.82	76.82
4	9	6	159.62	0.00	-96.60	96.60	125.53	0.00	-76.82	76.82
5										
20										

MAX LOAD CASE 1:		LRFD		ASD	
(X-X LOADING)					
	Bolt 2	Tension (T)=	159.62 lbs	Tension (T)=	125.53 lbs
	Bolt 1	Shear (V)=	96.60 lbs	Shear (V)=	76.82 lbs

kpff Consulting Engineers 45 Fremont Street, 28th Floor San Francisco, California 94105 (415) 989-1004 FAX (415) 989-1552	project:		
	location:		
	client:		
	EQUIPMENT ANCHORAGE-WALL MOUNTED		

EQUIPMENT ANCHORAGE-WALL MOUNTED

REFERENCE: 2022 CBC, ASCE 7-16 Chapter 13

FASTENER FORCES: LOAD CASE 2: SEISMIC LOADING IN Y-Y DIRECTION + Z-Z DIRECTION

LRFD LOAD CASE:	1.2	DL+	1.0	EL
ASD LOAD CASE:	1.00	DL+	0.7	EL

$$\begin{aligned}
 M_x &= (F_v * EL_{factor} + W_p * DL_{factor}) * -e_y + (F_h * EL_{factor}) * -e_z = \textbf{-1236} \quad \textbf{-865.5} \text{ lb*in} \\
 M_y &= (F_v * EL_{factor} + W_p * DL_{factor}) * e_x = \textbf{3477.6} \quad \textbf{2765.5} \text{ lb*in} \\
 M_z &= (F_h * EL_{factor}) * e_x = \textbf{2384.6} \quad \textbf{1669.2} \text{ lb*in}
 \end{aligned}$$

$$\begin{aligned}
 T_{fastener} &= M_y * d_z / I_z - M_z * d_y / I_y && \text{(negative tension indicates compression)} \\
 V_{y \text{ fastener}} &= F_h * EL_{factor} / (m * n) - M_x * d_z / I_p \\
 V_{z \text{ fastener}} &= M_x * d_y / I_p - (W_p * DL_{factor} + F_{pv} * EL_{factor}) / (m * n) \\
 V_r &= (V_y^2 + V_z^2)^{0.5}
 \end{aligned}$$

Bolt #	d _y (in)	d _z (in)	LRFD LEVEL				ASD LEVEL			
			T (lbs)	V _y (lbs)	V _z (lbs)	V _r (lbs)	T (lbs)	V _y (lbs)	V _z (lbs)	V _r (lbs)
1	-9	-6	-78.66	50.39	-72.82	88.55	-68.86	35.27	-60.18	69.75
2	-9	6	211.14	82.09	-72.82	109.74	161.60	57.46	-60.18	83.21
3	9	-6	-211.14	50.39	-120.38	130.50	-161.60	35.27	-93.46	99.90
4	9	6	78.66	82.09	-120.38	145.71	68.86	57.46	-93.46	109.72
5										
6										
20										

MAX LOAD CASE 2:		LRFD		ASD	
(X-X LOADING)		Bolt 2	Tension (T)= 211.14 lbs	Tension (T)=	161.60 lbs
		Bolt 4	Shear (V)= 145.71 lbs	Shear (V)=	109.72 lbs

GOVERNING LOADS:		LRFD		ASD	
Load Case 2	Bolt 2	Tension (T)=	211.14 lbs	Tension (T)=	161.60 lbs
Load Case 2	Bolt 4	Shear (V)=	145.71 lbs	Shear (V)=	109.72 lbs

CHANNEL NUT LOAD DATA
FOR 1½" (41 MM) WIDTH SERIES CHANNEL



MAXIMUM ALLOWABLE PULL-OUT AND SLIP LOADS

Channel Nut Size/Thread	Gage	Channel	Allowable Pull-Out Strength		Resistance to Slip		Torque	
			Lbs	kN	Lbs	kN	Ft Lbs	Nm
¾" - 10	12	P1000 P3000 P5000 P5500	2500	11.1	1700	7.6	125*	170
5/8" - 11			2500	11.1	1500	6.7	100*	135
15/16" - 12			2000	8.9	1500	6.7	50	70
7/8" - 14			1400	6.2	1000	4.4	35	50
9/8" - 16			1000	4.4	800	3.6	19	25
5/8" - 18			800	3.6	500	2.2	11	15
1/4" - 20			600	2.7	300	1.3	6	8

kpff Consulting Engineers
 45 Fremont Street, 28th Floor
 San Francisco, California 94105
 (415) 989-1004 FAX (415) 989-1552

project:
 location:
 client:
EQUIPMENT ANCHORAGE-WALL MOUNTED

EQUIPMENT ANCHORAGE-WALL MOUNTED



REFERENCE: 2022 CBC, ASCE 7-16 Chapter 13

Equipment ID = **Water Heater**
 Equipment Description = **Water Heater - Wall Mounted**
 Base Material = **Wall Mounted**
 W_p = weight of equipment = **25** lb
 l = overall length = **12** in
 w = overall width = **6** in
 d = overall depth = **12** in

Center of Mass Location
 CG_x = dist. in x-dir from Origin = **6** in
 CG_y = dist. in y-dir from Origin = **3** in
 CG_z = dist. in z-dir from Origin = **8** in
 n = # of anchors = **2**
 m = # of fastener @ each anchor = **1**

Seismic Accelerations
 a_p = amplification factor = **1**
 R_p = response factor = **2.5**
 S_{DS} = spectral acceleration = **1.2**
 $\Omega_0 F_h$ = ASCE 7-10: 13.3-1, 13.3-2, 13.3-3 = **28.8** lb
 $\Omega_0 F_v$ = vertical force = $0.2 S_{DS} W_p$ = **12** lb

Bolt Group Properties
 x_{bar} = y-dist. of C.R. from Origin = **0** in
 y_{bar} = y-dist. of C.R. from Origin = **3** in
 z_{bar} = z-dist. of C.R. from Origin = **6** in
 e_x = x-eccen. of C.G. from C.R. = **6** in
 e_y = y-eccen. of C.G. from C.R. = **0** in
 e_z = z-eccen. of C.G. from C.R. = **2** in
 $I_y = \sum(d_y^2) =$ **18.0 in²**
 $I_z = \sum(d_z^2) =$ **0.0 in²**
 $I_{polar} = I_y + I_z =$ **18.0 in²**



I_p = Imp. Factor = **1** $z =$ **1** ft
 Ω_0 = Over. Factor = **2** $h =$ **1** ft
 Apply $\Omega_0 =$ **Yes**
 $= 1.16 W_p$ **LRFD DESIGN**
 $= 0.48 W_p$ **LRFD DESIGN**

ANCHOR LOCATIONS (UP TO 20 ANCHORS)

Bolt #	Y (W)	Z (L)	d_y	d_z	d_y^2	d_z^2	d^2
1	0.00	6.00	-3.0	0.0	9.0	0.0	9.0
2	6.00	6.00	3.0	0.0	9.0	0.0	9.0
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							

SUM = $\sum d^2$ **18**

kpff Consulting Engineers 45 Fremont Street, 28th Floor San Francisco, California 94105 (415) 989-1004 FAX (415) 989-1552	project:		
	location:		
	client:		
	EQUIPMENT ANCHORAGE-WALL MOUNTED		

EQUIPMENT ANCHORAGE-WALL MOUNTED

REFERENCE: 2022 CBC, ASCE 7-16 Chapter 13

FASTENER FORCES: LOAD CASE 1: SEISMIC LOADING IN X-X DIRECTION + Z-Z DIRECTION

LRFD LOAD CASE:	1.2	DL+	1.0	EL
ASD LOAD CASE:	1.0	DL+	0.7	EL

	LRFD	ASD	
$M_x = (F_v * EL_{factor} + W_p * DL_{factor}) * -e_y =$	0	0	lb*in
$M_y = (F_v * EL_{factor} + W_p * DL_{factor}) * e_x + (F_h * EL_{factor}) * -e_z =$	194.4	160.08	lb*in
$M_z = (F_h * EL_{factor}) * e_y =$	0	0	lb*in

$T_{fastener} = F_{ph} * EL_{factor} / (m * n) + M_y * d_z / I_z - M_z * d_y / I_y$ (negative tension indicates compression)
 $V_{y \text{ fastener}} = -M_x * d_z / I_p$
 $V_{z \text{ fastener}} = M_x * d_y / I_p - (W_p * DL_{factor} + F_{pv} * EL_{factor}) / (m * n)$
 $V_r = (V_y^2 + V_z^2)^{0.5}$

			LRFD LEVEL				ASD LEVEL			
Bolt #	d _y (in)	d _z (in)	T (lbs)	V _y (lbs)	V _z (lbs)	V _r (lbs)	T (lbs)	V _y (lbs)	V _z (lbs)	V _r (lbs)
1	-3	0	#DIV/0!	0.00	-21.00	21.00	#DIV/0!	0.00	-16.70	16.70
2	3	0	#DIV/0!	0.00	-21.00	21.00	#DIV/0!	0.00	-16.70	16.70
3										
4										
5										
20										

MAX LOAD CASE 1:		LRFD		ASD	
(X-X LOADING)					
					lbs
Bolt 1	Shear (V)=	21.00 lbs		Shear (V)=	16.70 lbs



Consulting Engineers
45 Fremont Street, 28th Floor
San Francisco, California 94105
(415) 989-1004 FAX (415) 989-1552

project:

location:

client:

EQUIPMENT ANCHORAGE-WALL MOUNTED

EQUIPMENT ANCHORAGE-WALL MOUNTED

REFERENCE: 2022 CBC, ASCE 7-16 Chapter 13

FASTENER FORCES: LOAD CASE 2: SEISMIC LOADING IN Y-Y DIRECTION + Z-Z DIRECTION

LRFD LOAD CASE:	1.2	DL+	1.0	EL
ASD LOAD CASE:	1.00	DL+	0.7	EL

$$M_x = (F_v * EL_{factor} + W_p * DL_{factor}) * -e_y + (F_h * EL_{factor}) * -e_z = \text{LRFD } -57.6 \text{ ASD } -40.32 \text{ lb*in}$$

$$M_y = (F_v * EL_{factor} + W_p * DL_{factor}) * e_x = \text{LRFD } 252 \text{ ASD } 200.4 \text{ lb*in}$$

$$M_z = (F_h * EL_{factor}) * e_x = \text{LRFD } 172.8 \text{ ASD } 120.96 \text{ lb*in}$$

$$T_{fastener} = M_y * d_z / I_z - M_z * d_y / I_y \quad (\text{negative tension indicates compression})$$

$$V_{y \text{ fastener}} = F_h * EL_{factor} / (m * n) - M_x * d_z / I_p$$

$$V_{z \text{ fastener}} = M_x * d_y / I_p - (W_p * DL_{factor} + F_{pv} * EL_{factor}) / (m * n)$$

$$V_r = (V_y^2 + V_z^2)^{0.5}$$

Bolt #	d _y (in)	d _z (in)	LRFD LEVEL				ASD LEVEL			
			T (lbs)	V _y (lbs)	V _z (lbs)	V _r (lbs)	T (lbs)	V _y (lbs)	V _z (lbs)	V _r (lbs)
1	-3	0	#DIV/0!	14.40	-11.40	18.37	#DIV/0!	10.08	-9.98	14.18
2	3	0	#DIV/0!	14.40	-30.60	33.82	#DIV/0!	10.08	-23.42	25.50
3										
4										
5										
6										
20										

MAX LOAD CASE 2:		LRFD		ASD	
(X-X LOADING)		#DIV/0!	Tension (T)= #DIV/0! lbs	#DIV/0!	Tension (T)= #DIV/0! lbs
Bolt 2			Shear (V)= 33.82 lbs		Shear (V)= 25.50 lbs

GOVERNING LOADS:		LRFD		ASD	
Load Case 2 Bolt 2			Shear (V)= 33.82 lbs		Shear (V)= 25.50 lbs

CHANNEL NUT LOAD DATA
FOR 1½" (41 MM) WIDTH SERIES CHANNEL



MAXIMUM ALLOWABLE PULL-OUT AND SLIP LOADS

Channel Nut Size/Thread	Gage	Channel	Allowable Pull-Out Strength		Resistance to Slip		Torque	
			Lbs	kN	Lbs	kN	Ft Lbs	Nm
¾" - 10	12	P1000 P3000 P5000 P5500	2500	11.1	1700	7.6	125*	170
5/8" - 11			2500	11.1	1500	6.7	100*	135
15/16" - 12			2000	8.9	1500	6.7	50	70
7/8" - 14			1400	6.2	1000	4.4	35	50
9/8" - 16			1000	4.4	800	3.6	19	25
5/8" - 18			800	3.6	500	2.2	11	15
1/4" - 20			600	2.7	300	1.3	6	8

kpff

45 Fremont Street, 28th Floor
 San Francisco, CA 94105
 415-989-1004 www.kpff.com

project

location

client

by

date

job no.

sheet no.

Max Weight = 135 lbs

per ASCE7-16 Table 13.6-1 , plumbing

$a_p = 1$

$R_p = 2.5$

$\Omega = 2$

$SDS = 1.2$

$z/h = 0.9$

$$F_p = 0.4a_p \cdot SDS \cdot W_p \cdot (1 + 2z/h) / (R_p / I_p) = 0.53W_p$$

= 72 lbs

$$F_v = 0.2 \cdot SDS \cdot W_p = 32.4 \text{ lbs}$$

Threaded Rod Tensile Strength:

$$60 \text{ ksi} \times \pi \times (3/16)^2 = 6.6 \text{ kips} \gg 135 \text{ lbs} + 32.4 \text{ lbs}$$

lbs --> ok!

Withdrawal Check:

$$M_{Fp} = F_p \cdot 12" + (W_p + F_v) \cdot 2" = 1200 \text{ lb-inch}$$

$$T_{Fp} = 1200 \text{ lb-in} / 3" = 400 \text{ lbs pull out}$$

5/8" x 1 1/2" lag screw withdrawal capacity per

NDS Table 12.2A = 447 per inch x 0.9

(permanent load) = 402.6 lbs > 400 lbs --> ok!

Shear Check:

$$V_u = 135 + 33 = 168 \text{ lbs}$$


5/8" x 1 1/2" lag screw shear capacity per NDS

$$\text{Table 12K} = 440 \text{ lbs} \times 0.9 \times 0.5 = 198 \text{ lbs} \rightarrow$$

ok!

Minimum end distance for $C_{\Delta} = 0.5$ is $2D$

$$= 2 \times 5/8" = 1.25" < 1.5"$$




PLUMBING PIPE SUPPORT DETAIL


WIND LOADING ANALYSIS - Roof Components and Cladding Per ASCE 7-16 Code for Bldgs. of Any Height with Gable Roof $\theta \leq 45^\circ$ or Monoslope Roof $\theta \leq 3^\circ$ Using Part 1 & 3: (Chapter 30.3) for Low-Rise Buildings and (Chapter 30.5) for Buildings > 60 ft				
Job Name:		Subject:		
Job Number:		Originator:	Checker:	

Input Data:

Wind Speed, V =	92	mph (Wind Map, Fig 26.5-1A-D)
Bldg. Classification =	II	(Table 1.5-1 Occupancy Category)
Exposure Category =	C	(Sect. 26.7)
Ridge Height, hr =	13.00	ft. (hr $\geq$ he)
Eave Height, he =	10.75	ft. (he $\leq$ hr)
Building Width =	22.50	ft. (Normal to Building Ridge)
Building Length =	35.00	ft. (Parallel to Building Ridge)
Roof Type =	Gable	(Gable or Monoslope)
Topo. Factor, Kzt =	1.00	(Sect. 26.8 & Figure 26.8-1)
Direct. Factor, Kd =	0.85	(Table 26.6-1)
Gnd. Elev. Factor, Ke =	1.00	(Table 26.9-1)
Enclosed? (Y/N)	Y	(Sect. 28.6-1 & Figure 26.11-1)
Hurricane Region?	N	
Component Name =	Decking	(Purlin, Joist, Decking, or Fastener)
Effective Area, Ae =	16.875	ft. ² (Area Tributary to C&C)
Overhangs? (Y/N)	Y	(if used, overhangs on all sides)



Plan



Elevation

Resulting Parameters and Coefficients:

Roof Angle, θ =	11.31	deg.
Mean Roof Ht., h =	11.88	ft. (h = (hr+he)/2, for roof angle >10 deg.)

Roof External Pressure Coefficients, GCp:

GCp All Zones (+) =	0.48	(Fig. 30.3-2A, 30.3-2B, 30.3-2C, and 30.3-2D)
GCp Zone 1,2e (-) =	-2.50	(Fig. 30.3-2A, 30.3-2B, 30.3-2C, and 30.3-2D)
GCp Zone 2n,2r (-) =	-3.26	(Fig. 30.3-2A, 30.3-2B, 30.3-2C, and 30.3-2D)
GCp Zone 3e (-) =	-3.68	(Fig. 30.3-2A, 30.3-2B, 30.3-2C, and 30.3-2D)
GCp Zone 3r (-) =	-4.15	(Fig. 30.3-2A, 30.3-2B, 30.3-2C, and 30.3-2D)

Positive & Negative Internal Pressure Coefficients, GCpi (Figure 26.11-1):

+GCpi Coef. =	0.18	(positive internal pressure)
-GCpi Coef. =	-0.18	(negative internal pressure)

If $z \leq 15$ then: $K_z = 2.01 \cdot (15/zg)^{2/\alpha}$, If $z > 15$ then: $K_z = 2.01 \cdot (z/zg)^{2/\alpha}$ (Table 30.3-1)

α =	9.50	(Table 26.9-1)
zg =	900	(Table 26.9-1)
Kh =	0.85	(Kh = Kz evaluated at z = h)

Velocity Pressure: $q_h = 0.00256 \cdot K_h \cdot K_{zt} \cdot K_d \cdot K_e \cdot V^2$ (Eq. 26.10-1)

q_h =	15.63	psf $q_h = 0.00256 \cdot K_h \cdot K_{zt} \cdot K_d \cdot K_e \cdot V^2$ (q_z evaluated at z = h)
---------	-------	--

Design Net External Wind Pressures (Sect. 30.3 & 30.5):

For h $\leq$ 60 ft.: $p = q_h \cdot (GCp - (+/-GCpi))$ (psf)

For h > 60 ft.: $p = q \cdot (GCp - qi \cdot (+/-GCpi))$ (psf)

where: q = q_h for roof


qi = q_h for roof (conservatively assumed per Sect. 30.5)

Wind Load Tabulation for Roof Components & Cladding								
Component	z (ft.)	Kh	qh (psf)	p = Net Design Pressures (psf)				
				All Zones (+)	Zone 1,2e (-)	Zone 2n,2r (-)	Zone 3e (-)	Zone 3r (-)
Decking	0.00	0.85	15.63	10.35	-41.90	-53.72	-60.31	-67.77
	For z = hr:	13.00	0.85	15.63	10.35	-41.90	-53.72	-60.31
	For z = he:	10.75	0.85	15.63	10.35	-41.90	-53.72	-60.31
	For z = h:	11.88	0.85	15.63	10.35	-41.90	-53.72	-60.31

- Notes: 1. (+) and (-) signs signify wind pressures acting toward & away from respective surfaces.
2. Width of Zone 1 & 2 (edge), '0.6*a' = 1.80 ft.
3. Width of Zone 3 (corner), '0.6*a' & '0.2*a' = 1.80 0.60 ft.
4. For monoslope roofs with $\theta \leq 3$ degrees, use Fig. 30.4-2A for 'GCp' values with 'qh'.
5. For buildings with $h > 60'$ and $\theta > 10$ degrees, use Fig. 30.6-1 for 'GCpi' values with 'qh'.
6. For all buildings with overhangs, use Fig. 30.4-2B for 'GCp' values per Sect. 30.10.
7. If a parapet $\geq 3'$ in height is provided around perimeter of roof with $\theta \leq 7$ degrees,
Negative Zone 3 shall be treated as Zone 2; Positive Zone 2 & 3 shall be treated as Zone 4 & 5
8. Per Code Section 30.2.2, the minimum wind load for C&C shall not be less than 16 psf.
9. References : a. ASCE 7-16, "Minimum Design Loads for Buildings and Other Structures".


TABLE 1.2 – Fastener Wind Uplift Design Load – Wood Substrates:

Nominal Thickness of Wood Deck		T1.2 - Fastener Wind Uplift Design Strength, PSF										
		Consealor #14-13 DP1 Screws in Wood Substrates										
		Clip Spacing (Span) in Feet										
2 Screws per Clip	7/16" OSB	13.6	14.8	16.3	18.1	20.4	23.3	27.2	32.6	40.8	54.4	81.6
	19/32" OSB	29.1	31.7	34.9	38.8	43.6	49.8	58.1	69.8	87.2	116.3	174.4
	23/32" OSB	40.6	44.3	48.7	54.2	60.9	69.6	81.2	97.5	121.9	162.5	243.7
	1/2" Plywood	38.6	42.1	46.3	51.4	57.9	66.1	77.2	92.6	115.7	154.3	231.5
	5/8" Plywood	42.2	46.1	50.7	56.3	63.3	72.4	84.4	101.3	126.7	168.9	253.3
	3/4" Plywood	55.6	60.7	66.8	74.2	83.5	95.4	111.3	133.5	166.9	222.6	333.9
	2x4 SYP	88.1	96.1	105.7	117.5	132.1	151.0	176.2	211.4	264.3	352.4	528.5



2. Design loads are factored loads for use with LRFD Load Combinations. A resistance factor, Φ , of 0.40 has been applied in accordance with AWC-NDS.

FIGURE 1.3: No. 16 Gauge Standard Clip – Material Properties and Figures (Typical)



16 Gauge Standard Clip Properties

Thickness	0.0566 in. (min)	S_{xe} (top)	0.1520 in ³	ϕP_n (E-TF)	0.473 k
Type	A653/A792 S5-33	S_{xe} (bot)	0.2454 in ³		
F_y	33 ksi (min)	I_x	0.2634 in ⁴		
E	29,500 ksi				

ZONE 3r
Penetration Depth = 5/8"
Nominal Capacity at 3' - 0" spacing = 84.4 psf
Penetration reduction factor = 0.625
LRFD to ASD conversion = $1/0.4 = 2.5$
Actual capacity = $84.4 \times 0.625 \times 2.5 = 131.875$ psf

Factored max wind demand (3r) = 0.6×67.77 psf = 40.66 psf
Factor of Safety = 2

$$DCR = 40.66 \times 2 / 131.875 < 1$$

Spacing 3' - 0" acceptable for zone 3r.

All other zones:


Penetration Depth = 5/8"
Nominal Capacity at 3' - 6" spacing = 72.4 psf
Penetration reduction factor = 0.625
LRFD to ASD conversion = $1/0.4 = 2.5$
Actual capacity = $72.4 \times 0.625 \times 2.5 = 113.125$ psf

Factored max wind demand (3r) = 0.6×60.31 psf = 36.2 psf
Factor of Safety = 2


$$DCR = 36.2 \times 2 / 113.125 < 1$$

Spacing 3' - 6" acceptable for zone 3r.

Roof Components and Cladding:



Roof Zones for Buildings with $h \leq 60$ ft.
(for Gable Roofs $\leq 45^\circ$ and Monoslope Roofs $\leq 3^\circ$)



Roof Zones for Buildings with $h > 60$ ft.
(for Roofs $\leq 7^\circ$)




Originally Issued: 06/05/2020

Revised: 06/06/2022

Valid Through: 06/30/2023

FIGURE 1.6 – Series 300 – 0.040-inch and 0.050-inch thick Aluminum:



**TABLE 1.13 – 0.040-thick Aluminum Section Properties:
.040" Aluminum x 18" Panel Properties**

Thickness	0.040 in. (nom)	I _x (top)	0.450 in ⁴	øM _n (top)	4.02 k-in
Type	3105-H25	I _x (bot)	0.430 in ⁴	øM _n (bot)	5.42 k-in
Width	18 in. (nom)			øV _n	1.340 k
F _y	19 ksi				
E	10,100 ksi				

For SI: 1 inch = 2.54 mm; 1 ksi = 6.89 MPa; 1 kip = 1000 lbs.

Notes:

1. Section properties are calculated in accordance with the ADM1-2015, Aluminum Design Manual: Part 1-A Specification for Aluminum Structures.
2. The section properties also shall be used for the 0.050-inch panels.
3. The 0.050- and 0.040-inch aluminum panel loads may be designed by a registered design professional using the Section Properties in Table 1.13 of this report.
4. E is the modulus of elasticity.
5. F_y is the yield strength.
6. I_{xe} is the effective moment of inertia about the cross-section about the x-axis.
7. M_n is the nominal bending strength.
8. V_n is the nominal shear strength.

Check Panel Strength:

Trib Width of Panel = Building Width / 2 = 22.5' / 2 = 11.25'

W = 66.8 psf x 11.25' = 751.5 plf

Mu = WL²/8 = 751.5 x (1.5)² / 8 = 211 lbs-ft = 2.5 kip-in < Mn listed in Table 1.13 above --> OK!

For clip capacity, see Table 1.16 in ER 686 shown below:

Allowed wind load = 141 psf >> 66.7 psf

TABLE 1.16 – Clip Wind Negative (Uplift) Design Load:

T1.16 Series 300 Panel/Clip Wind Uplift Design Load, PSF										
.040" or .050" Aluminum with 18" o.c. Seam Spacing										
Standard 16 GA Clip Anchors										
Clip Spacing (Span), Feet										
	6.0	5.5	5.0	4.5	4.0	3.5	3.0	2.5	2.0	1.5
Max. Design Load, PSF	44.8	55.5	66.2	77.0	87.7	98.4	109.1	119.8	130.6	141.3

For SI: 1 inch = 25.4 mm; 1 foot = 305 mm; 1 psf = 47.9 Pa

1. The wind uplift nominal strength has been determined according to the procedures of AISI S906, with a resistance factor, $\Phi = 0.80$ in accordance with AISI S100-12 D6.2.1.
2. Design loads shown are factored loads for use with LRFD load combinations.
3. Intermediate design values have been determined based on linear interpolation between tested values based on Section 5.4.3.2 of EC011-2019.
4. The allowable service load deflections for metal roof panels shall be taken as L/60.
5. Wind uplift design loads may be further limited by the design strength of the anchor fasteners into the roof substrate. The tests conducted in accordance with ASTM E1592, shown in this table, utilized two 1/4" -14 x 1.25" HWH self-drilling tapping screws per anchor/ purlin connection. For other fastener types or roof substrates, the faster design strength shall be designed by the registered design professional.
6. Tables 1.1 and 1.2 of this report have been provided for the fastener design strength of a frequently used screw type into typical metal and wood roof substrates.