

**SAN RAFAEL CITY SCHOOLS  
310 Nova Albion Way  
San Rafael, CA 94903**

**ADDENDUM NO. 2**

**TO**

**Request for Proposals  
Energy Conservation and Energy Efficiency Services  
Mechanical Equipment Replacement**

**Addendum Date: November 26, 2018**

This Addendum provides for:

**CLARIFICATIONS AND RESPONSES TO QUESTIONS FROM PROPOSERS RECEIVED.**

The San Rafael City Schools has received the following questions, and provide responses as noted. In addition, where a clarification is provided that will be included below.

1. Question: Re-Davidson Middle School “Per the scope of Work Section PART 1, Item #2, Sub Item #2 reads Install VFD on Air Handler Unit on Boiler. This does not make sense. Please confirm that this was meant to read Air Handler Unit on Roof, which would be referencing AH-1.”
  - a. **Answer: Yes, the VFD is to be installed on the Air Handler, AH-1.**
2. Question: Re-Glenwood Elementary “Please confirm that Furnace serving Multi-Purpose room is not part of this scope.”
  - a. **Answer: Yes, this furnace is not in the scope for this project.**
3. Question: Re-San Rafael High School “Please confirm it is acceptable to control the above referenced AC unit with Stand Alone Thermostat.”
  - a. **Answer: Yes, that is acceptable.**

**[END OF ADDENDUM]**